ø22 Switches & Pilot Lights

HW Series



Complete with finger-safe contact blocks. Ensure safety and save wiring time.















- DC-DC converter types are not approved by standards.
- See website for details on approvals and standards.

First in the industry! Six different colors with a single LED (LSRD)

IS03864-4 safety color compliant

The bright and clears colors are suited for emergency situations

• Illuminated selector switches (illumination color: S (Blue), PW (Pure white))


Safety colors are defined with ISO standards.

• Illuminated pushbuttons (illumination color: S (Blue)) • Pilot lights - round flush (illumination color: S (Blue))

*Except for products below


Previously, 5 different color LEDs were required but with the new illuminated unit, only a single LED is used. Only the lens needs to be replaced to change the illumination color.

The new LED reduces maintenance time, makes stock control easier, and is environmentally friendly.



High visibility with new LED (LSRD)

Brighter and clearer compared to conventional LEDS



HW Series Selection Guide

Function			Pushbutton		
Category	Flush	Extended	ø29mm Mushroom	ø40mm Mushroom	ø60mm Mushroom
Category	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	Momentary
Shape					
Model	HW1B-M1 HW1B-A1	HW1B-M2 HW1B-A2	HW1B-M3 HW1B-A3	HW1B-M4 HW1B-A4	HW1B-M5
Page	B-187	B-187	B-187	B-187	B-187

Function			Pushbutton		
Category	Square Flush	Square Extended	Round Flush w/Square Bezel	Round Extended w/Square Bezel	ø29mm Mushroom w/Square Bezel
	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained
Shape					
Model	HW2B-M1 HW2B-A1	HW2B-M2 HW2B-A2	HW3B-M1 HW3B-A1	HW3B-M2 HW3B-A2	HW3B-M3 HW3B-A3
Page	B-188	B-188	B-189	B-189	B-189

Function		Pilot Light						
Category	Flush (Marking)	Extended (Dome)	Square Flush (Marking)	Jumbo Dome				
Shape	*	*						
Model	HW1P-1	HW1P-2	HW2P-1	HW1P-5				
Page	B-190	B-190	B-190	B-190				

Function			Illuminated Pushbutton		
Category	Flush	Extended	Extended w/Full Shroud	Square Flush	Flush w/Square Bezel
Category	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained
Shape					
Model	HW1L-M1 HW1L-A1	HW1L-M2 HW1L-A2	HW1L-MF2 HW1L-AF2	HW2L-M1 HW2L-A1	HW3L-M1 HW3L-A1
Page	B-192	B-192	B-193	B-194	B-194

Function		Illuminated Pushbuttor	ì	Short-body pilot light (LED)		
Category	Flush	Extended	Extended w/Full Shroud	Flush	Extended (Dome)	Square Flush
Category	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	Flusii	Extended (Dome)	Square Flush
Shape						
Model	HW1L-M3 HW1L-A3	HW3L-M3 HW3L-A3	HW1L-M4 HW1L-A4	HW1P-1J	HW1P-2J	HW2P-1J
Page	B-195	B-195	B-196	Web	Web	Web

APEM

Switches &

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors
AUTO-ID

Flush Silhouette

ø16

ø22 ø30

Miniature

....ataro

Pilot Lights

HW

TW

HW Series Selection Guide

Dual Pushbutton Function w/o Pilot Light w/ Pilot Light Flush (top) Flush (bottom) Flush (top) Extended (bottom) Flush (top) Flush (bottom) Flush (top) Flush (bottom) Category Momentary/Interlocking Momentary/Interlocking Momentary/Interlocking Momentary/Interlocking Shape HW7D-L11 HW7D-L21 HW7D-B11 HW7D-B21 HW7D-B12 HW7D-B22 HW7D-L12 HW7D-L22 Model Page

Function Category				1	Pushbutton Selector	
Shape						
Model	HW1S	HW1K-□P	HW1K	HW1F	HW1F-□L	HW1R
Page	B-203	B-204	B-206	B-208	B-209	B-214

Function	Mono-Lever Switch				
Category	Standard	Interlocking			
Shape					
Model	HW1M	HW1M-L			
Page	B-215	B-215			

APEM

Pilot Lights

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers Operator

Interfaces

Sensors AUTO-ID

Flush Silhouette

ø22

ø30

Miniature

Pilot Lights

HW TW

Ø22 HW Series Switches & Pilot Lights

Complete with finger-safe contact blocks Ensure safety and save wiring time

- Finger-safe terminal blocks
- · Self-cleaning rolling action contacts.
- Degree of protection: IP65 (except dual pushbutton: IP40)
- Dual pushbutton switches available with two pushbuttons and a pilot light integrated into one space-saving unit.
- A wide range of operating voltages for worldwide application.
- Six different colors with a single LED (LSRD). Only the lens needs to be replaced to change the illumination color.
- ISO3864-4 safety color compliant
 The bright and clears colors are suited for emergency situations



Application for dual pushbuttons:

Ideal for use as power switches and start/stop switches (available with I/ON and O/OFF markings on the buttons and a pilot light in the center).

Interlock type prevents two pushbuttons from being pressed at the same time, providing the best solution for up/down switches.

APEM

Switches &

Control Boxes

Emergency Stop Switches Enabling Switches

0-(-1-0--1--1-

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit

Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Specifications and Ratings

Contact Ratings

Pushbuttons	Rated insulation voltage	600V
Illuminated Pushbuttons Dual Pushbuttons	Rated continuous current	10A
Selector Switches Illuminated Selector Switches Selector Pushbuttons	Contact ratings by utilization category IEC60947-5-1	AC-15 (A600) DC-13

Flush Silhouette

ø16

ø22

ø30

Miniature

Pilot Lights

Contact Ratings by Utilization Category

HW-U10 (NO contact), HW-U01 (NC contact)

Operating Voltage AC AC-12 Control of resistive loads and solid state loads		24V	48V	50V	110V	220V	440V	
AC Operating 50/60 Hz	AC	AC-12 Control of resistive loads and solid state loads	10A	_	10A	10A	6A	2A
	50/60 Hz	AC-15 Control of electromagnetic loads (> 72 VA)	10A	_	7A	5 A	3A	1A
Current		DC-12 Control of resistive loads and solid state loads	10A	5A	_	2.2A	1.1A	_
		DC-13 Control of electromagnets	5A	2A		1.1A	0.6A	

TW YOU


HW-U10R (EM contact/NO contact), HW-U01R (LB contact/NC contact)

Operating Voltag	ge		24V	48V	50V	110V	220V	440V
AC Operating 50/60 Hz	AC-12 Control of resistive loads and solid state loads	5A	_	5A	5 A	3 A	1A	
	50/60 Hz	AC-15 Control of electromagnetic loads (> 72 VA)	5A	_	3.5A	2.5A	1.5A	0.5A
Current	DC	DC-12 Control of resistive loads and solid state loads	5A	2.5A	_	1.1A	0.55A	_
	DC	DC-13 Control of electromagnets	2.5A	1A	_	0.55A	0.3A	_

- The operating current represents the classification by making and breaking currents (IEC 60947-5-1).
- · Contact materials: Silver contacts
- Minimum applicable load: 3V AC/DC, 5 mA (applicable range may vary with operating conditions and load types)

ø22 HW Series Switches & Pilot Lights

HW-U Contact Block



Part No.	HW-U10	HW-U01	HW-U10R	HW-U01R		
Contact	_/_	7	_/_	7		
Comaci	1NO	1NC	EM (NO) (early make)	LB (NC) (late break)		
Contact No.	3-4	1-2	3-4	1-2		
Housing	Blue	Purple red	Blue	Purple red		
Push Rod	Green	Red	Black	White		
Weight	Approx. 11g					

- Up to 2 layers (4 blocks) can be attached.
- · Gold contacts available (gold-plated silver)

LED Illuminated Part Specifications

Unit					LED	lamp
UIIIL	Rated Vo	tage	Operating Vol	tage	Lamp Base	Part No.
	6V AC/DC		6V AC/DC			LSRD-6
	12V AC/DC		12V AC/DC	1	BA9S/13	LSRD-1
	24V AC/DC		24V AC/DC	1		LSRD-2
Illuminated pushbutton	100/110V AC		100/110V AC	±10%		
Illuminated selector switch	115/120V AC		115/120V AC (*1)			LSRD-6
Pilot light	200/220V AC		200/220V AC	±1070		
Dual pushbutton	230/240V AC	50/60 Hz	230/240V AC (*1)	7		
(with pilot light)	380V AC		380V AC			
	400/440V AC		400/440V AC			
	480V AC		480V AC			
	110V DC		90 to 140V DC			

- See B-182, for details on LED lamp ratings.
- For the LED lamp used in jumbo dome pilot lights and dual pushbutton switches (with pilot light), see B-182.

• Yellow (Y) cannot be used with dual pushbuttons.

Illuminated Part Type and Shape

		Illuminated Unit	Pilot Light				
Power Unit	Full voltage adapter	Transforme	er	DC-DC converter	Full voltage adapter	Transformer	DC-DC converter
Rated Voltage	6, 12, 24V AC/DC	100 to 240V AC	380V AC min.	110V DC	6, 12, 24V AC/DC	100 to 480V AC	110V DC
Polarity	None	None	None	X1 (+) X2 (–)	None	None	X1 (+) X2 (-)
Shape/Terminal	X1	X1 X2	X1 X2		X1 X2		X1 X2

APEM Control Boxes

Emergency Stop Switches Enabling Switches Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets Protectors Power Supplies

LED Illumination

Operator Sensors

AUTO-ID

Flush Silhouette

ø30 Miniature Pilot Lights

TW YW

LED Lamp Ratings

LSRD - Except jumbo dome pilot lights (except colors R, A, and G)

Part No.		LSRD-6 LSRD-1 LSRD-2					
Lamp Base		BA9S/13					
Rated Voltag	е	6V AC/DC	12V AC/DC	24V AC/DC			
Voltage Rang	ge	6V AC/DC ±10%	12V AC/DC ±10%	24V AC/DC ±10%			
Current	DC	10mA	7mA	7mA			
Draw	AC	14mA	8mA	8mA			
Voltage Mark	king	Die stamped on the base					
Life (reference value)		Approx, 50,000 hours (The luminance is reduced to 50% the initial intensity when used on complete DC at 25°C.)					
Internal Circuit X1 — Limited current circuit Noise protection circuit Rectifier circuit Dimmer protection circuit				2			
Weight		Approx. 2g					

- Only one color is available for LSRD so there are no codes to specify the color in the part no.
- Use a LSRD-2 lamp for dome pilot lights with Y (yellow), S (blue), or PW (pure white) illumination.
- \bullet For G (green) dual pushbuttons (with pilot light), use a LSRD lamp and an attachment lens.

LSTDB - For jumbo dome pilot lights HW1P-5Q4 only (except colors Y, S, and PW)

Part No.	LSTDB-2AN	LSTDB-2GN						
Lamp Base	BA9S/13							
Voltage Range	24V AC/DC±10%							
Current Draw	14mA	8mA						
Rated Voltage	24V AC/DC							
Life (reference value)	Approx. 20,000 hours (The luminance is reduced to 50% the	Approx. 20,000 hours (The luminance is reduced to 50% the initial intensity when used on complete DC at 25°C.)						
Internal Circuit	X1 — Limited current circuit Noise protection circuit Rectifier circuit Dimmer protection circu	G T	LED chip Rectifier diode Zener diode Resistor					

- Use an A (amber) LED for (R) red illumination.
- Use a LSRD-2 lamp for dome pilot lights with Y (yellow), S (blue), or PW (pure white) illumination.

APEM

Switches &

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Operator Interfaces Sensors

Flush Silhouette

ø16

ø22

ø30

Miniature

Pilot Lights

HW

TW

Non-illuminated: -25 to +60°C (no freezing)

Specifications


ilot Light	Operating Temperature	Illuminated: -25 to +50°C (no freezing) Jumbo dome pilot lights: -25 to +55°C (no freezing)				
ght	Operating Humidity	45 to 85% RH (no condensation)				
0,	Storage Temperature	-40 to +80°C (no freezing)				
	Contact Resistance	50 mΩ maximum (initial value)				
APEM	Insulation Resistance	100 MΩ minimum (500V DC megger)				
Switches & Pilot Lights	Dielectric Strength	Between live and dead metal parts: 2,500V AC, 1 minute (Full voltage and illuminated units: 2,000V AC, 1 minute) (*1)				
Control Boxes	Vibration Resistance	Damage limits: 30 Hz, amplitude 1.5 mm				
Emergency	VIDIALION NESISTANCE	Operating extremes: 5 to 55 Hz, amplitude 0.5 mm				
Stop Switches	Shock Resistance	Damage limits: 1,000m/s ²				
Enabling Switches	SHOCK NESISTANCE	Operating extremes: 100m/s ²				
Safety Products		Pushbutton, Illuminated pushbutton Momentary······5,000,000				
Explosion Proof		Maintained				
Terminal Blocks	Mechanical Life (minimum	Selector switch				
Relays & Sockets	operations)	Key selector switch (Pin tumbler)100,000				
Circuit		Illuminated selector switch				
Protectors		Mono-lever switches · · · · · · 250,000				
Power Supplies		Pushbutton, Illuminated pushbutton				
LED Illumination		Momentary···········500,000 (*2) Maintained·······500,000 (*4)				
Controllers		Dual pushbutton··················500,000 (*2) Selector switch··················500,000 (*3)				
Operator Interfaces	Electrical Life (*5)	Key selector switch (Disc tumbler)······500,000 (*3) Key selector switch (Pin tumbler)·····100,000 (*3)				
Sensors		Illuminated selector switch······500,000 (*3)				
AUTO-ID		Pushbutton selector 250,000 (*3) Mono-lever switches 250,000 (*4)				
		66g (HW1B-M122) 20g (HW1P-1Q4) 84g (HW1L-M122Q4)				
Flush Silhouette		66g (HW1S-2T22) 94g (HW1K-2A22)				
ø16	Weight (Apporox.)	72g (HW1K-2JPC11) 84g (HW1F-222Q4)				
ø22		71g (HW1R-2A22) [′] 82g (HW1M-2222-22N9)				
ø30		72g (HW7D-B1111111) 90g (HW7D-L111111Q4)				
Miniature	*1) Dielectric strength for dual nuchbuttons are as follows:					

- *1) Dielectric strength for dual pushbuttons are as follows: Full voltage type: 1,000V AC, 1 minute (between live and dead metal parts) Transformer and DC-DC converter types: 2,000V AC, 1 minute (between live and dead metal parts)
- *2) Switching frequency 1,800 operations/h, duty ratio 40%
- *3) Switching frequency 1,200 operations/h, duty ratio 40%
- *4) Switching frequency 900 operations/h, duty ratio 40%
- *5) Load condition 220V AC, 3A (AC-15)

Mounting Hole Layout

All dimensions in mm.

Panel Cut (IEC60947-5-1)



- The minimum mounting centers are applicable to switches with one layer of contact blocks (one to two contact blocks). When two layers of contact blocks are mounted, determine the minimum mounting centers in consideration of convenience for wiring.
- When high temperature is expected, take necessary measures such as securing sufficient mounting centers or using a cooling fan.

Minimum Mounting Centers

(Dimensions in mm)

Unit	A (*6)	B (*7)
ø40mm mushroom button	50	40
Pushbutton selector	50	50
Mono-lever switch	72	72
Pilot light	30	30
Jumbo dome pilot light	85	85
Dual pushbutton switch	55	30
Illuminated selector switch	50	50

 When using the safety lever lock, determine the vertical spacing (*6) in consideration of convenience for installing and removing the safety lever lock, (Recommended vertical spacing: 100 mm)

The minimum length of vertical spacing (*6) is 45 mm when safety lever lock is not used.

 The 3.2 mm recess is for preventing rotation and is not necessary when the nameplate or anti-rotation ring is not used.

Degree of Protection

Unit	IEC 60529
All units except dual pushbutton switches	IP65 (*8)
Dual pushbutton switches	IP40 (*9)

^{*8)} When using a nameplate with the HW series, IP65 protection degree is achieved only when nameplates shown on B-216 are used. (IP40 when other ø22 namplates such as NWA are used)

Ordering Information

Standard models

- Specify Ordering No. when ordering.
- Specify a button or lens color code in place of *.
- · Pilot lights, illuminated pushbuttons, and illuminated selector switches have an LED lamp installed unless otherwise specified.
- Nameplates and accessories for mono-lever switch are ordered separately. See B-216 to B-218.

Pilot Lights

TW

^{*9)} IP65 protection degree when HW9Z-D7D button cover is used.

Ordering Information

Pushbuttons (B-187 to B-189)

When specifying gold-plated silver contact and contact configuration:

```
HW1B-M1 <u>11</u> R -<u>MAU</u>
                                   Optional contact
                                                          MAU: Gold contact
                                   Contact configuration
                                                         10:
                                                                1N0
                                                          01:
                                                                1NC
                                                                1N01NC
                                                          11:
                                                          20:
                                                                2N0
                                                         02:
                                                                2NC
                                                          22:
                                                                2N02NC
                                                          40:
                                                                4N0
                                                         04:
                                                                4NC
                                                                1N03NC
                                                          13:
                                                          31:
                                                                3N01NC
                                                          30:
                                                                3N0
                                                          03:
                                                                3NC
                                                          12:
                                                                1N02NC
```

Pilot Lights (B-190)

When specifying LED operating voltage:

```
HW1P-1 <u>H2</u> R
                                  Operating voltage
                                                        Q0:
                                                             Without LED lamp
                                                        Q2:
                                                              6V AC/DC
                                                        Q3:
                                                              12V AC/DC
                                                             24V AC/DC
                                                        04:
                                                       H2:
                                                              100/110V AC
                                                        H22:
                                                             115/120V AC
                                                             200/220V AC
                                                        M2:
                                                       M42: 230/240V AC
                                                             380V AC
                                                       S2:
```

2N01NC

400/440V AC

480V AC

110V DC

21:


T2:

T82:

D2:

Illuminated Pushbuttons (B-192 to B-196)

When specifying gold-plated silver contact, contact configuration, and LED operating voltage:



Note:

Odd number of contact blocks, such as 1NO, 1NC, 3NO, 2NO-1NC, 1NO-2NC, and 3NC, is not available for transformer type or DC-DC converter type.

2N01NC

APEM

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets Circuit

Protectors

Power Supplies LED Illumination

Controllers Operator

Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30 Miniature

Pilot Lights

TW

APEM

Control Boxes

Stop Switches Enabling Switches

Safety Products

Explosion Proof
Terminal Blocks

Relays & Sockets

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø30

TW

YW

Miniature

Pilot Lights


Protectors
Power Supplies

Emergency

Ordering Information


Dual Pushbutton Switches [without pilot light] (B-199)

When specifying gold-plated silver contact and contact configuration:



Dual Pushbutton Switches [with pilot light] (B-200)

When specifying gold-plated silver contact, contact configuration, and LED operating voltage:




Note: Only the below combinations are possible.

Contact configuration					
Top button Button button					
1NO	1NC				
1NO	1N0				
1NO-1NC	1NO-1NC				
2N0	2NC				

Ordering Information

Key Selector Switches (Pin Tumbler Key) (B-204 to B-205)

When specifying gold-plated silver contact, key removal position, and key number:



MAU: Gold-plated silver

-501 - 515

2-position A: Removable in all positions

B: Removable in the left only

C: Removable in the right only

3-position A: Removable in all positions

B: Removable in the left and center

C: Removable in the right and center

D: Removable in center only E: Removable in right and left

G: Removable in left only

H: Removable in right only

Blank, J, or S

2-position, maintained

2-position, spring return from right 21:

3: 3-position, maintained

31: 3-position, spring return from right

3-position, spring return from left


33: 3-position, spring return two way

Note:

- The key cannot be removed in a spring return position.
- The key number is engraved on the key cylinder. (default key is not engraved with a number)

Key Selector Switches (Disc Tumbler Key) (B-206 to B-207)

When specifying gold-plated silver contact, key removal position, and key number:



MAU: Gold-plated silver

-1H, -2H, -3H


(same as pin tumbler key shown above) (same as pin tumbler key shown above)

(same as pin tumbler key shown above)

- The key cannot be removed in a spring return position.
- The key number is engraved on the key cylinder. (default key is not engraved with a number)

Illuminated Selector Switches (B-208 to B-209)

When specifying gold-plated silver contact and LED operating voltage:



MAU: Gold-plated silver

Without LED lamp 200/220V AC Q0: M2: Q2: 6V AC/DC M42: 230/240V AC Q3: 12V AC/DC S2: 380V AC 24V AC/DC 400/440V AC 04T2: 100/110V AC T82: 480V AC

Н2-H22: 115/120V AC

Blank (Knob), L (Lever)

Blank, J, or S

2-position, maintained

21: 2-position, spring return from right

3: 3-position, maintained

3-position, spring return from right 31.

32: 3-position, spring return from left

33: 3-position, spring return two way

Selector Switches (B-203)

When specifying gold-plated silver contact

HW1S- 2T11 - MAU

Optional contact

MAU: Gold-plated silver

• See B-203 for operator position.

APFM

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit

Protectors Power Supplies

LED Illumination

Controllers Operator

Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30 Miniature

Pilot Lights

TW

Flush / Extended / Mushroom Pushbuttons

APEM	
Switches & Pilot Lights	
Control Boxes	
Emergency Stop Switches	
Enabling Switches	
Safety Products	
Explosion Proof	
Terminal Blocks	
Relays & Sockets	
Circuit Protectors	
Power Supplies	
LED Illumination	
Controllers	
Operator Interfaces	
Sensors	
AUTO-ID	
Flush Silhouette	
ø16	
ø22	
ø30	
	- 1

TW
YW

Miniature Pilot Lights

					Package Quantity: 1
Shape	Operation	Contact	Part No.	Color Code	Dimensions (mm)
Flush		1N0	HW1B-M110*		
HW1B-M1		1NC	HW1B-M101*		a.t.i
HW1B-A1	Momentary	1NO-1NC	HW1B-M111*		Gasket Locking Ring Panel Thickness 0.8 to 6
	Wiomontary	2N0	HW1B-M120*	В	→ Cr
		2NC	HW1B-M102*	G	
		2NO-2NC	HW1B-M122*	R	
		1N0	HW1B-A110*	Y	
7 (1NC	HW1B-A101*	S W	
	Maintained	1NO-1NC	HW1B-A111*	"	49.4 (1 or 2 blocks) 0.5 (29.4) 69.4 (3 or 4 blocks)
	mamamou	2N0	HW1B-A120*		<u> </u>
		2NC	HW1B-A102*		
		2NO-2NC	HW1B-A122*		
Extended		1NO	HW1B-M210*		
HW1B-M2		1NC	HW1B-M201*		
HW1B-A2	Momentary	1NO-1NC	HW1B-M211*		Gasket Locking Ring \ Panel Thickness 0.8 to 6
		2N0	HW1B-M220*	В	Locking Ring Panel Thickness 0.8 to 6
		2NC	HW1B-M202*	G	
		2NO-2NC	HW1B-M222*	R	
		1NO	HW1B-A210*	Y S	
a H		1NC	HW1B-A201*	w	
	Maintained	1NO-1NC	HW1B-A211*		49.4 (1 or 2 blocks) 69.4 (3 or 4 blocks) 13
		2N0	HW1B-A220*		
		2NC	HW1B-A202*		
		2NO-2NC	HW1B-A222*		
ø29mm Mushroom	Momentary	1NO	HW1B-M310*	B G R	
HW1B-M3 HW1B-A3		1NC	HW1B-M301*		Gasket
I IIW ID-AS		1NO-1NC	HW1B-M311*		Panel Thickness 0.8 to 6
		2N0	HW1B-M320*		
		2NC	HW1B-M302*		
		2NO-2NC	HW1B-M322*		
		1NO 1NC	HW1B-A310*	Ś	
		1NO-1NC	HW1B-A301* HW1B-A311*	w	49.4 (1 or 2 blocks) 13
	Maintained	2N0	HW1B-A320*	-	69.4 (3 or 4 blocks) 23.2 29.4
		2NC	HW1B-A320*		
		2NO-2NC	HW1B-A302*	-	
# 40 man Mushus - ***		1NO	HW1B-M410*		
ø40mm Mushroom HW1B-M4		1NC	HW1B-M401*	-	
HW1B-A4		1NO-1NC	HW1B-M411*		Gasket
_	Momentary	2N0	HW1B-M420*	1	Locking Ring \ Panel Thickness 0.8 to 6
		2NC	HW1B-M402*	В	
		2NO-2NC	HW1B-M422*	G R	
		1NO	HW1B-A410*	Ϋ́	
		1NC	HW1B-A401*	S	
		1NO-1NC	HW1B-A411*	W	40.4 (1 or 2 Marks) 3.5
	Maintained	2N0	HW1B-A420*	1	49.4 (1 or 2 blocks) 13 69.4 (3 or 4 blocks) 23,2
		2NC	HW1B-A402*	1	
		2NO-2NC	HW1B-A422*	1	
ø60mm Mushroom		1NO	HW1B-M510*		Gasket Panel Thickness 0.8 to 6
HW1B-M5		1NC	HW1B-M501*		Locking Ring
	Momentary	1NO-1NC	HW1B-M511*	В	
	Womontary	2N0	HW1B-M520*	G R	
		2NC	HW1B-M502*		0.5
		2NO-2NC	HW1B-M522*		49.4 (1 or 2 blocks) 15 29.4 69.4 (3 or 4 blocks) 30.1
	1	1			i e e e e e e e e e e e e e e e e e e e

- Specify a color code in place of * in Part No. B (black), G (green), R (red), Y (yellow), S (blue), W (white)
- Pushbuttons with 1 or 3 contact blocks have a dummy block.
- See B-184 for other contact configurations and gold-plated silver contacts.
- Pushbuttons: M3.5 Terminal screws integrated terminal cover




Square Flush / Square Flush Pushbuttons

Package Quantity: 1


Shape	Operation	Contact	Part No.	Color Code	Dimensions (mm)		
Square Flush		1N0	HW2B-M110*				
HW2B-M1		1NC	HW2B-M101*				
HW2B-A1	Mamantan	1NO-1NC	HW2B-M111*		Gasket		
_	Momentary	2N0	HW2B-M120*		Locking Ring Panel Thickness 0.8 to 6		
		2NC	HW2B-M102*	B G			
		2NO-2NC	HW2B-M122*	R			
		1N0	HW2B-A110*	Υ			
N H		1NC	HW2B-A101*	S W			
	Maintained	1NO-1NC	HW2B-A111*	VV	9.4 (1 or 2 blocks)		
	Maintained	2N0	HW2B-A120*		69.4 (3 or 4 blocks) 13		
		2NC	HW2B-A102*				
		2NO-2NC	HW2B-A122*				
Square Extended	Momentary	1N0	HW2B-M210*				
HW2B-M2		1NC	HW2B-M201*				
HW2B-A2		1NO-1NC	HW2B-M211*		Gasket		
		2N0	HW2B-M220*	1	Locking Ring Panel Thickness 0.8 to 6		
		2NC	HW2B-M202*	B G			
		2NO-2NC	HW2B-M222*	Ř			
		1N0	HW2B-A210*	Y			
		1NC	HW2B-A201*	S W			
	Maintained	1NO-1NC	HW2B-A211*		0.5		
	iviaiiitaiiied	2N0	HW2B-A220*		49.4 (1 or 2 blocks) 13 29.4 (3 or 4 blocks) 19		
		2NC	HW2B-A202*	1			
		2NO-2NC	HW2B-A222*				

- Specify a color code in place of * in Part No. B (black), G (green), R (red), Y (yellow), S (blue), W (white)
- Pushbuttons with 1 or 3 contact blocks have a dummy block.
- See B-184 for other contact configurations and gold-plated silver contacts.
- Pushbuttons: M3.5 Terminal screws

Bottom View



1NO contact block



3 contact blocks



2/4 contact blocks

- For 1NC contact, the contact block will mount on the opposite side.
- See B-227 for wiring.
- Integrated terminal cover

APEM

Switches &

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination
Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

W22

ø30

Miniature

Pilot Lights

HW

TW

Round Flush / Round Extended / Mushroom with Square Bezel

Package Quantity: 1

APEM Control Boxes Emergency Stop Switches Enabling Switches Safety Products Explosion Proof Terminal Blocks Relays & Sockets Protectors Power Supplies LED Illumination Controllers Operator Sensors AUTO-ID

Flush Silhouette ø16

Miniature

ø30

Pilot Lights


Dimensions (mm) Shape Operation Contact Part No. Color Code HW3B-M110* 1N0 Round Flush with Square Bezel HW3B-M1 1NC HW3B-M101* HW3B-A1 1NO-1NC HW3B-M111* Momentary 2N0 HW3B-M120* Panel Thickness 0.8 to 6 2NC HW3B-M102* G 2NO-2NC HW3B-M122* R Υ 1N0 HW3B-A110* S 1NC HW3B-A101* W 1NO-1NC HW3B-A111* 49.4 (1 or 2 blocks) Maintained 2N0 HW3B-A120* 2NC HW3B-A102* 2NO-2NC HW3B-A122* 1N0 HW3B-M210* Round Extended with Square Bezel 1NC HW3B-M201* HW3B-M2 1NO-1NC HW3B-M211* Momentary HW3B-A2 2N0 HW3B-M220* В 2NC HW3B-M202* G R 2NO-2NC HW3B-M222* Υ 1N0 HW3B-A210* S 1NC HW3B-A201* W 1NO-1NC HW3B-A211* Maintained 69.4 (3 or 4 blocks) 2N0 HW3B-A220* 2NC HW3B-A202* 2NO-2NC HW3B-A222* 1N0 HW3B-M310* ø29mm Mushroom HW3B-M301* 1NC with Square Bezel HW3B-M3 1NO-1NC HW3B-M311* HW3B-A3 Momentary HW3B-M320* 2N0 Panel Thickness 0.8 to 6 HW3B-M302* 2NC G 2NO-2NC HW3B-M322* R Υ 1N0 HW3B-A310* S 1NC HW3B-A301* W 1NO-1NC HW3B-A311* Maintained 49.4 (1 or 2 blocks) 69.4 (3 or 4 blocks) 2N0 HW3B-A320* 2NC HW3B-A302* 2NO-2NC HW3B-A322*

- Specify a color code in place of * in Part No. B (black), G (green), R (red), Y (yellow), S (blue), W (white)
- Pushbuttons with 1 or 3 contact blocks have a dummy block.
- See B-184 for other contact configurations and gold-plated silver contacts.
- Pushbuttons: M3.5 Terminal screws


Bott

YW

Bottom View



1NO contact block



3 contact blocks



2/4 contact blocks

- For 1NC contact, the contact block will mount on the opposite side.
- See B-227 for wiring.
- · Integrated terminal cover

Round Flush / Dome / Square Flush / Jumbo Dome Pilot Lights

Package Quantity: 1

	Package Quantity: 1						
Shape	Lamp	Operating Voltage	Part No.	Color Code			
Round Flush (marking type) HW1P-1		24V AC/DC	HW1P-1Q4*		Pilot Lights		
24V AC/DC	LED	100/110V AC	HW1P-1H2*	R G Y A S	APEM Switches & Pilot Lights Control Boxes Emergency		
With transformer (100/110V AC)		200/220V AC	HW1P-1M2*	PW	Stop Switches Enabling Switches Safety Products Explosion Proof		
Dome HW1P-2		24V AC/DC	HW1P-2Q4*		Terminal Blocks Relays & Sockets		
					Circuit Protectors		
				R C	Power Supplies		
(24V AC/DC)	LED	100/110V AC	HW1P-2H2*	G Y A S PW	LED Illumination		
12.50					Controllers		
		200/220V AC	HW1P-2M2*		Operator Interfaces		
					Sensors		
With transformer (100/110V AC)					AUTO-ID		
Square Flush (marking type)							
HW2P-1		24V AC/DC	HW2P-1Q4*		Flush Silhouette		
					ø16		
			HW2P-1H2*	R G	ø22		
(24V AC/DC)	LED	100/110V AC		Y A	ø30		
The state of the s				S PW	Miniature		
					Pilot Lights		
		200/220V AC	HW2P-1M2*				
With transformer (100/110V AC)					HW		
Jumbo Dome Pilot Light (*1)					TW		
HW1P-5					YW		
	LED	24V AC/DC	HW1P-5Q4*	R G Y A S PW			

- Specify a color code in place of * in Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)
- \bullet Pilot lights have an LED lamp installed unless otherwise specified.
- See B-184 for other operating voltages.
- See B-191 for bottom view.
- See B-191 for how to specify units without LED lamps.
- *1) Jumbo dome pilot lights contain an exclusive LED. See B-182 and B-221.



Dimensions All dimensions in mm.

Pilot Lights


Round Flush Terminal screws: M3.5, integrated terminal cover


Extended Terminal screws: M3.5, integrated terminal cover

6, 12, 24V AC/DC, Without LED lamp


6, 12, 24V AC/DC, Without LED lamp

100/110V AC, 200/220V AC (240V AC maximum)





110V DC, 380V AC minumum



APEM

Control Boxes Emergency

Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks Relays & Sockets

Protectors

Power Supplies


Controllers Operator Interfaces Sensors

AUTO-ID


LED Illumination

Locking Ring






110V DC, 380V AC minimum




Square Flush Terminal screws: M3.5, integrated terminal cover

6, 12, 24V AC/DC, Without LED lamp


11.5







110V DC, 380V AC minimum



Flush Silhouette ø16


> ø30 Miniature

Pilot Lights

TW

YW


Jumbo Dome Pilot Light Terminal screws: M3.5, integrated terminal cover



Panel Cut-Out


Mounting Centers (Except jumbo dome)

Close mounting on 30 mm centers



When mounting 100/110V AC, 200/220V AC, 110V DC units on 30mm centers vertically and horizontally, keep the ambient temperature below 40°C.

Mounting Centers (Jumbo dome)



Determine the minimum mounting centers in consideration of convenience for wiring.

Pilot Light Bottom View

6, 12, 24V AC/DC Without LED lamp 100/110V AC, 200/220V, 110V DC





- For DC-DC Converter types, terminal X1 is ⊕, X2 is⊖.
- See B-228 for wiring.

APEM

Control Boxes

Emergency
Stop Switches

Enabling
Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit
Protectors

Power Supplies

LED Illumination

Controllers

Operator

Sensors AUTO-ID

Flush Silhouette

ø16

ø30
Miniature
Pilot Lights

TW

LED

Round Flush / Round Extended (Marking Type)

						Package Quantit		
Shape	Illumination	Operation	Rated Voltage	Contact Configuration	Part No.	Color Code		
Round Flush (Marking type)				1NO	HW1L-M110Q4*			
W1L-M1				1NC	HW1L-M101Q4*			
W1L-A1			24V AC/DC	1NO-1NC	HW1L-M111Q4*			
			211710700	2N0	HW1L-M120Q4*			
				2NC	HW1L-M102Q4*	R		
				2NO-2NC	HW1L-M122Q4*	G		
		Momentary		1NO-1NC	HW1L-M111H2*	Y		
		Momontary	100/110V AC	2N0	HW1L-M120H2*	A		
			100/1101/10	2NC	HW1L-M102H2*	S PW		
4				2NO-2NC	HW1L-M122H2*			
				1NO-1NC	HW1L-M111M2*			
(24V AC/DC)			200/220V AC	2N0	HW1L-M120M2*			
			200/2201/10	2NC	HW1L-M102M2*			
	LED -			2NO-2NC	HW1L-M122M2*			
				1NO	HW1L-A110Q4*			
				1NC	HW1L-A101Q4*			
			24V AC/DC	1NO-1NC	HW1L-A111Q4*			
			271 70/00	2N0	HW1L-A120Q4*			
				2NC	HW1L-A102Q4*	R		
				2N0-2NC	HW1L-A122Q4*	G		
		Maintained		1NO-1NC	HW1L-A111H2*	Υ		
U.M.		Mamameu	100/110V AC	2N0	HW1L-A120H2*	A		
				2NC	HW1L-A102H2*	S		
With transformer				2NO-2NC	HW1L-A122H2*	PW		
(100/110V AC)				1NO-1NC	HW1L-A111M2*			
(100/1101/10)			200/220V AC	2N0	HW1L-A120M2*			
				2NC	HW1L-A102M2*			
				2NO-2NC	HW1L-A122M2*			
ound Extended (Marking type)				1NO	HW1L-M210Q4*			
W1L-M2				1NC	HW1L-M201Q4*			
W1L-A2			247/ 40/00	1NO-1NC	HW1L-M211Q4*			
			24V AC/DC	2N0	HW1L-M220Q4*			
				2NC	HW1L-M202Q4*	R		
				2NO-2NC	HW1L-M222Q4*	Ğ		
1 I				1NO-1NC	HW1L-M211H2*	Ϋ́		
		Momentary	100/1101/40	2N0	HW1L-M220H2*	A		
			100/110V AC	2NC	HW1L-M202H2*	S		
				2NO-2NC	HW1L-M222H2*	PW		
				1NO-1NC	HW1L-M211M2*			
(24V AC/DC)			200/2004 42	2N0	HW1L-M220M2*			
(214710/00)			200/220V AC	2NC	HW1L-M202M2*			
				2NO-2NC	HW1L-M222M2*			
	LED -			1NO	HW1L-A210Q4*			
				1NC	HW1L-A201Q4*			
			0.41/ 4.0/50	1NO-1NC	HW1L-A211Q4*			
			24V AC/DC	2N0	HW1L-A220Q4*			
				2NC	HW1L-A202Q4*	В		
				2NO-2NC	HW1L-A222Q4*	R G		
		84.1.1.1.1		1NO-1NC	HW1L-A211H2*	— G		
		Maintained	100 % 101 15	2N0	HW1L-A220H2*	Ä		
The same of the sa			100/110V AC	2NC	HW1L-A202H2*	S		
With transfermer				2NO-2NC	HW1L-A222H2*	PW		
With transformer				1NO-1NC	HW1L-A211M2*			
(100/110V AC)				2N0	HW1L-A220M2*			
			200/220VAC	2NC	HW1L-A202M2*			
	1		1	2110	THAT I MENERAL			

- Specify a color code in place of * in Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)
- \bullet Illuminated pushbuttons have an LED lamp installed unless otherwise specified.
- See B-184 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.
- See B-184 for other contact configurations and gold-plated silver contacts.
- Illuminated pushbutttons of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.
- See B-198 for bottom view.
- See B-184 for how to specify units without LED lamps.

ø22 HW Series Illluminated Pushbuttons

LED Round Extended with Full Shroud (Marking Type)

Package Quantity: 1

0							
Ē	Shape	Illumination	Operation	Rated Voltage	Contact	Part No.	Color Code
ot Lights	Round Extended with Full Shroud				1NO	HW1L-MF210Q4*	
ङ	(Marking type)				1NC	HW1L-MF201Q4*	
	HW1L-MF2			24V AC/DC	1NO-1NC	HW1L-MF211Q4*	
	HW1L-AF2			24V AC/DC	2N0	HW1L-MF220Q4*	
APEM					2NC	HW1L-MF202Q4*	
Switches &					2NO-2NC	HW1L-MF222Q4*	R G
Pilot Lights	T. II		Momentary		1NO-1NC	HW1L-MF211H2*	Ϋ́
Control Boxes			Womentary	100/110V AC	2N0	HW1L-MF220H2*	A
Emergency					2NC	HW1L-MF202H2*	S PW
Stop Switches					2NO-2NC	HW1L-MF222H2*	T VV
Enabling Switches					1NO-1NC	HW1L-MF211M2*	
Safety Products	(24V AC/DC)			200/220V AC	2N0	HW1L-MF220M2*	
- Suloty Froducto	(2147.0750)				2NC	HW1L-MF202M2*	
Explosion Proof		LED			2NO-2NC	HW1L-MF222M2*	
Terminal Blocks		LED			1NO	HW1L-AF210Q4*	
Torrina Brooke					1NC	HW1L-AF201Q4*	
Relays & Sockets	_			24V AC/DC	1NO-1NC	HW1L-AF211Q4*	
Circuit					2N0	HW1L-AF220Q4*	
Protectors					2NC	HW1L-AF202Q4*	
Power Supplies					2NO-2NC	HW1L-AF222Q4*	R G
LED Illumination			Maintained		1NO-1NC	HW1L-AF211H2*	Ϋ́
			Maintaineu	100/110V AC	2N0	HW1L-AF220H2*	A
Controllers				100/110V AC	2NC	HW1L-AF202H2*	S PW
Operator	With transformer				2NO-2NC	HW1L-AF222H2*	T VV
Interfaces	(100/110V AC)				1NO-1NC	HW1L-AF211M2*	
Sensors				200/220V AC	2N0	HW1L-AF220M2*	
AUTO-ID				200/220V AU	2NC	HW1L-AF202M2*	
7,010 10					2NO-2NC	HW1L-AF222M2*	

- Specify a color code in place of * in Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)
- \bullet Illuminated pushbuttons have an LED lamp installed unless otherwise specified.
- See B-184 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.
- See B-184 for other contact configurations and gold-plated silver contacts.
- Illuminated pushbutttons of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.
- See B-198 for bottom view.

Flush Silhouette

ø30

Miniature

Pilot Lights

TW

LED

Square Flush / Round Flush with Square Bezel (Marking Type)

Packade Quantity:	age Quantity:	
-------------------	---------------	--

						Package Quantity: 1	₫ _
Shape	Illumination	Operation	Illumination	Contact	Part No.	Color Code	Pilot Lights
Square Flush (Marking type)				1NO	HW2L-M110Q4*	_	ght
HW2L-M1				1NC	HW2L-M101Q4*	_	· σ
HW2L-A1			24V AC/DC	1NO-1NC	HW2L-M111Q4*		
				2N0	HW2L-M120Q4*	_	
				2NC	HW2L-M102Q4*	— R	APEM
A STATE OF THE STA				2NO-2NC	HW2L-M122Q4*	G	Switches &
		Momentary		1NO-1NC	HW2L-M111H2*	Y A	Pilot Lights
			100/110V AC	2NO 2NC	HW2L-M120H2*	$ \stackrel{A}{S}$	Control Boxes
				2NO-2NC	HW2L-M102H2* HW2L-M122H2*	PW	Emergency
				1NO-1NC	HW2L-M111M2*	-	Stop Switches
				2N0	HW2L-M120M2*	\dashv	Enabling Switches
(24V AC/DC)			200/220V AC	2NC	HW2L-M102M2*		Safety Products
				2NO-2NC	HW2L-M122M2*		- Culoty 1 Toddets
	LED :			1NO	HW2L-A110Q4*		Explosion Proof
				1NC	HW2L-A101Q4*		Terminal Blocks
			0.41/ 4.0/00	1NO-1NC	HW2L-A111Q4*	7	- ICHIIIIAI DIUCKS
			24V AC/DC	2N0	HW2L-A120Q4*		Relays & Socket
				2NC	HW2L-A102Q4*	R	Circuit
				2NO-2NC	HW2L-A122Q4*	G	Protectors
		Maintained		1NO-1NC	HW2L-A111H2*	Y A	Power Supplies
- CO.		Mamameu	100/110V AC	2N0	HW2L-A120H2*	S	
			100/1107 AC	2NC	HW2L-A102H2*	PW	LED Illumination
With transformer				2NO-2NC	HW2L-A122H2*		Controllers
(100/110V AC)				1NO-1NC	HW2L-A111M2*		Operator
			200/220V AC	2N0	HW2L-A120M2*		Interfaces
				2NC	HW2L-A102M2*		Sensors
				2NO-2NC	HW2L-A122M2*		
Round Flush with Square Bezel				1NO	HW3L-M110Q4*	_	AUTO-ID
Marking type) IW3L-M1				1NC	HW3L-M101Q4*	_	
1W3L-N1			24V AC/DC	1NO-1NC	HW3L-M111Q4*	_	
				2NO 2NC	HW3L-M120Q4*	R	
		Momentary		2NO-2NC	HW3L-M102Q4* HW3L-M122Q4*	⊢ G	Flush Silhouette
The state of the s			100/110V AC	1NO-1NC	HW3L-M111H2*	Ϋ́	ø16
A PARTY OF THE PAR				2N0	HW3L-M120H2*	- A	0 10
				2NC	HW3L-M102H2*	– S	ø22
				2NO-2NC	HW3L-M122H2*	PW	ø30
The second second				1NO-1NC	HW3L-M111M2*	╡	930
			000/5	2N0	HW3L-M120M2*	╡	Miniature
(0.4)(A.O.(D.O.)			200/220V AC	2NC	HW3L-M102M2*	7	Dilat Liabta
(24V AC/DC)				2NO-2NC	HW3L-M122M2*	7	Pilot Lights
	LED			1NO	HW3L-A110Q4*		
				1NC	HW3L-A101Q4*		
			24V AC/DC	1NO-1NC	HW3L-A111Q4*	_	LIW .
Author			24V AU/DU	2N0	HW3L-A120Q4*	_	HW
				2NC	HW3L-A102Q4*	R	TW
				2NO-2NC	HW3L-A122Q4*	G	
		Maintained		1NO-1NC	HW3L-A111H2*	Y	YW
U and			100/110V AC	2N0	HW3L-A120H2*	A	
				2NC	HW3L-A102H2*	S PW	
With transformer				2NO-2NC	HW3L-A122H2*	_ ·"	
(100/110V AC)				1NO-1NC	HW3L-A111M2*	_	
,			200/220V AC	2N0	HW3L-A120M2*	_	
				2NC	HW3L-A102M2*	_	
				2NO-2NC	HW3L-A122M2*		

- Specify a color code in place of * in Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)
- Illuminated pushbuttons have an LED lamp installed unless otherwise specified.
- See B-184 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.
- See B-184 for other contact configurations and gold-plated silver contacts.
- Illuminated pushbutttons of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.
- See B-198 for bottom view.

LED Mushroom (ø29mm) / Mushroom (ø29mm) with Square Bezel (Marking Type)

Package Quantity: 1

ot Lights	Shape	Illumination	Operation	Illumination	Contact	Part No.	Color Code
igh	ø29mm Mushroom				1N0	HW1L-M310Q4*	
ङ	(Marking type)				1NC	HW1L-M301Q4*	
	HW1L-M3			24V AC/DC	1NO-1NC	HW1L-M311Q4*	
	HW1L-A3			24V AG/DG	2N0	HW1L-M320Q4*	
APEM					2NC	HW1L-M302Q4*	R
Switches &					2NO-2NC	HW1L-M322Q4*	G
Pilot Lights			Momentary		1NO-1NC	HW1L-M311H2*	Υ
Control Boxes			Momontary	100/110V AC	2N0	HW1L-M320H2*	A S
Emergency					2NC	HW1L-M302H2*	PW
Stop Switches					2NO-2NC	HW1L-M322H2*	
Enabling Switches					1NO-1NC	HW1L-M311M2*	
	(24V AC/DC)			200/220V AC	2NO 2NC	HW1L-M320M2*	_
Safety Products	(24V AO/DC)				2NC-2NC	HW1L-M302M2* HW1L-M322M2*	_
Explosion Proof		LED			1NO	HW1L-A310Q4*	
<u> </u>					1NC	HW1L-A301Q4*	_
Terminal Blocks					1NO-1NC	HW1L-A311Q4*	-
Relays & Sockets				24V AC/DC	2N0	HW1L-A320Q4*	
Circuit					2NC	HW1L-A302Q4*	
Protectors					2NO-2NC	HW1L-A322Q4*	⊢ R ∟ G
Power Supplies					1NO-1NC	HW1L-A311H2*	- u
			Maintained	100/110/110	2N0	HW1L-A320H2*	Α
LED Illumination				100/110V AC	2NC	HW1L-A302H2*	S
Controllers	Mills transformer				2NO-2NC	HW1L-A322H2*	PW
	With transformer (100/110V AC)				1NO-1NC	HW1L-A311M2*	
Operator Interfaces	(100/1107 A0)			200/220V AC	2N0	HW1L-A320M2*	
Sensors				200/220V A0	2NC	HW1L-A302M2*	
					2NO-2NC	HW1L-A322M2*	
AUTO-ID	ø29mm Mushroom with Square				1NO	HW3L-M310Q4*	
	Bezel (Marking type)				1NC	HW3L-M301Q4*	
	HW3L-M3 HW3L-A3			24V AC/DC	1NO-1NC	HW3L-M311Q4*	
	I IIWSL-AS				2N0	HW3L-M320Q4*	
Flush Silhouette					2NC 2NO-2NC	HW3L-M302Q4*	_ R
ø16					1NO-1NC	HW3L-M322Q4* HW3L-M311H2*	G Y
910			Momentary		2N0	HW3L-M320H2*	A
ø22				100/110V AC	2NC	HW3L-M302H2*	S
ø30					2NO-2NC	HW3L-M322H2*	PW
					1NO-1NC	HW3L=M311M2*	
Miniature				000/0001/40	2N0	HW3L-M320M2*	
Pilot Lights	(24V AC/DC)			200/220V AC	2NC	HW3L-M302M2*	
riiot Lights	,,	LED			2NO-2NC	HW3L-M322M2*	
		LED	<u> </u>		1NO	HW3L-A310Q4*	
					1NC	HW3L-A301Q4*	
HW				24V AC/DC	1NO-1NC	HW3L-A311Q4*	
HW				217710720	2N0	HW3L-A320Q4*	
TW					2NC	HW3L-A302Q4*	R
					2NO-2NC	HW3L-A322Q4*	G
YW			Maintained		1NO-1NC	HW3L-A311H2*	_ Y
				100/110V AC	2N0	HW3L-A320H2*	A S
					2NC	HW3L-A302H2* HW3L-A322H2*	PW
	With transformer				2NO-2NC 1NO-1NC	HW3L-A322H2*	
	(100/110V AC)				2NO	HW3L-A320M2*	-
				200/220V AC	2NC	HW3L-A302M2*	
					2NO-2NC	HW3L-A322M2*	
							1

- Specify a color code in place of * in Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)
- $\bullet \ \, \text{Illuminated pushbuttons have an LED lamp installed unless otherwise specified.}$
- \bullet See B-184 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.
- \bullet See B-184 for other contact configurations and gold-plated silver contacts.
- \bullet Illuminated pushbutttons of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.
- See B-198 for bottom view.

LED

Mushroom (ø40mm) (Marking Type)

Package Quantity: 1

Shape	Illumination	Operation	Illumination	Contact	Part No.	Color Code	
40mm Mushroom		•		1NO	HW1L-M410Q4*		ot Lights
Marking type)				1NC	HW1L-M401Q4*		र्ड
IW1L-M4			0.41/4.0/D0	1NO-1NC	HW1L-M411Q4*		
W1L-A4			24V AC/DC	2N0	HW1L-M420Q4*		
				2NC	HW1L-M402Q4*		APEM
				2NO-2NC	HW1L-M422Q4*	R G	Switches &
		Managadami		1NO-1NC	HW1L-M411H2*	Ϋ́	Pilot Lights
		Momentary	100/110V AC	2N0	HW1L-M420H2*	A	Control Boxes
			100/110V AC	2NC	HW1L-M402H2*	S PW	Emergency
				2NO-2NC	HW1L-M422H2*	PW	Stop Switches
				1NO-1NC	HW1L-M411M2*		Enabling Switches
			200/220V AC	2N0	HW1L-M420M2*		Safety Products
(24V AC/DC)			200/220V AC	2NC	HW1L-M402M2*		- Odlety Froducts
	LED			2NO-2NC	HW1L-M422M2*		Explosion Proof
				1NO	HW1L-A410Q4*		Terminal Blocks
			24V AC/DC	1NC	HW1L-A401Q4*		- Torrisina Bioono
				1NO-1NC	HW1L-A411Q4*		Relays & Sockets
Appeal of the last			24V AC/DC	2N0	HW1L-A420Q4*		Circuit
				2NC	HW1L-A402Q4*		Protectors
				2NO-2NC	HW1L-A422Q4*	R G	Power Supplies
		Maintained		1NO-1NC	HW1L-A411H2*	Ϋ́	LED Illumination
		Mamameu	100/110V AC	2N0	HW1L-A420H2*	A	
			100/110V AC	2NC	HW1L-A402H2*	S PW	Controllers
				2NO-2NC	HW1L-A422H2*	- FVV	Operator
With transformer				1NO-1NC	HW1L-A411M2*		Interfaces
(100/110V AC)			200/2201/ 40	2N0	HW1L-A420M2*		Sensors
		İ	200/220V AC	2NC	HW1L-A402M2*		AUTO-ID
				2NO-2NC	HW1L-A422M2*		

- Specify a color code in place of * in Part No. R (red), G (green), Y (yellow), A (Amber), S (blue), PW (pure white)
- \bullet Illuminated pushbuttons have an LED lamp installed unless otherwise specified.
- See B-184 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.
- See B-184 for other contact configurations and gold-plated silver contacts.
- \bullet Illuminated pushbutttons of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.
- See B-198 for bottom view.

Flush Silhouette

ø16

022

ø30 Miniature

Pilot Lights

нw

TW

APEM

Control Boxes Emergency Stop Switches

Enabling Switches Safety Products

Explosion Proof

Terminal Blocks Relays & Sockets

Protectors Power Supplies LED Illumination

> Controllers Operator Interfaces

> > Sensors

AUTO-ID

Flush Silhouette

ø16

ø30

Miniature

Dimensions All dimensions in mm.


Illuminated Pushbuttons (Momentary / Maintained)


Round Flush Terminal screws: M3.5, integrated terminal cover


6, 12, 24V AC/DC, Without LED lamp

100/110V AC, 200/220V AC (240V maximum)

110V DC, 380V AC minimum









Round Extended Terminal screws: M3.5, integrated terminal cover


6, 12, 24V AC/DC, Without LED lamp

100/110V AC, 200/220V AC (240V maximum)

110V DC, 380V AC minimum










Round Extended with Full Shroud 6, 12, 24V AC/DC, Without LED lamp

Terminal screws: M3.5, integrated terminal cover 100/110V AC, 200/220V AC (240V maximum)

110V DC, 380V AC minimum









Square Flush Terminal screws: M3.5, integrated terminal cover


6, 12, 24V AC/DC, Without LED lamp

100/110V AC, 200/220V AC (240V maximum)

110V DC, 380V AC minimum









Flush with Square Bezel Terminal screws: M3.5, integrated terminal cover


6, 12, 24V AC/DC, Without LED lamp

100/110V AC, 200/220V AC (240V maximum)

110V DC, 380V AC minimum







Dimensions All dimensions in mm.

Illuminated Pushbuttons (Momentary / Maintained)

Ø29mm Mushroom Terminal screws: M3.5, integrated terminal cover

ø29mm Mushroom with Square Bezel Terminal screws: M3.5, integrated terminal cover

Ø40mm Mushroom with Square Bezel Terminal screws: M3.5, integrated terminal cover

6, 12, 24V AC/DC, Without LED lamp

6, 12, 24V AC/DC, Without LED lamp

69.4 (2 or 3 blocks)

6, 12, 24V AC/DC, Without LED lamp


100/110V AC, 200/220V AC (240V maximum)


110V DC, 380V AC minimum

110V DC, 380V AC minimum

110V DC, 380V AC minimum

89.5 (2 blocks), 109.5 (4 contacts







100/110V AC, 200/220V AC (240V maximum)

79.5 (2 blocks), 99.5 (4 contacts)

100/110V AC, 200/220V AC (240V maximum)

79.5 (2 blocks), 99.5 (4 blocks)





APEM

Emergency Stop Switches

Explosion Proof

Terminal Blocks

Relays & Sockets

Protectors

Power Supplies

LED Illumination

Controllers

Operator

Sensors

AUTO-ID

ø16

ø30

Miniature

Pilot Lights

TW

YW

Control Boxes


Enabling Switches

Safety Products


Interfaces


Flush Silhouette

Bottom View 6, 12, 24V AC/DC, Without LED lamp



3 contact blocks





100/110V AC, 200/220V AC



110V DC, 380V AC minimum

• For DC-DC Converter types, terminal X1 is ⊕, X2 is⊖.

• See B-227 to B-228 for wiring.

HW7D

Shape

Dual Pushbuttons (without Pilot Light)

Specify a button color code in place of 2 and legend code in place of 3 in the Part No.

Package Quantity: 1

	1
APEM	
Switches & Pilot Lights	
Control Boxes	
Emergency Stop Switches	
Enabling Switches	
Safety Products	
Explosion Proof	
Terminal Blocks	
Relays & Sockets	
Circuit Protectors	
Power Supplies	
LED Illumination	
Controllers	
Operator Interfaces	
Sensors	



Operation	Putton Ctulo	Button Style Conta		Part No.	2 Button Color Code	3 Legend Code
Operation	bullon Style	Top Button	Bottom Button	rait No.	Z Button Color Code	S Legena Code
		1NO	1NC	HW7D-B111001 2 3		
	Flush (top)	1NO	1NO	HW7D-B111010 2 3		
	Flush (bottom)	1NO-1NC	1NO-1NC	HW7D-B111111 2 3		
Momontary	entary	2N0	2NC	HW7D-B112002 2 3		
Momentary Flush (top) Extended (bot		1NO	1NC	HW7D-B121001 2 3		
	Flush (top) Extended (bottom)	1NO	1NO	HW7D-B121010 2 3		
		1NO-1NC	1NO-1NC	HW7D-B121111 2 3	GR: Green (top)	Blank: Without legend
		2N0	2NC	HW7D-B122002 2 3	Red (bottom)	1: I / ON (top)
		1NO	1NC	HW7D-B211001 2 3	WB: White (top)	0 / OFF (bottom)
	Flush (top)	1NO	1NO	HW7D-B211010 2 3	Black (bottom)	
	Flush (bottom)	1NO-1NC	1NO-1NC	HW7D-B211111 2 3		
Interlock (*1)		2N0	2NC	HW7D-B212002 2 3		
Interiock (1)		1NO	1NC	HW7D-B221001 2 3		
	Flush (top)	1NO	1NO	HW7D-B221010 2 3		
	Extended (bottom)	1NO-1NC	1NO-1NC	HW7D-B221111 2 3		
		2N0	2NC	HW7D-B222002 2 3		

- See B-202 for top and bottom button contact mounting positions.
- *1) Interlock: Momentary operation. When one of the buttons is pressed, the other button cannot be operated.

 Do not operate top and bottom buttons at the same time. Operating the buttons at the same time may lead to malfunctions.

Flush Silhouette

ø16

AUTO-ID

ø30

Miniature

Pilot Lights

TW YW

LED

HW7D

Dual Pushbuttons (with Pilot Light)

Specify a LED color code in place of 1, button color code in place of 2, and legend code in place of 3 in the Part No.

Package Quantity: 1

Shape	LED: LSRD-* (24V A	AC/DC)				O			APEM Switche Pilot Lig Control Emerge Stop Sv
Operation	Button Style	Illumination	Con Top	tact Bottom	Part No.	1LED	2 Button Color Code	3 Legend Code	Enabling Switche
			Button	Button					Safety F
			1NO	1NC	HW7D-L111001Q4 1 2 3				Fortest
	Flush (top)	24V AC/DC	1NO	1NO	HW7D-L111010Q4 1 2 3	ļ			Explosi
	Flush (bottom)	Z-1 NO/DO	1NO-1NC	1NO-1NC	HW7D-L1111111Q4 1 2 3	ļ			Termin
Momentary			2N0	2NC	HW7D-L112002Q4 1 2 3				Deleve
Wiementary			1NO	1NC	HW7D-L121001Q4 1 2 3				Relays
	Flush (top)	24V AC/DC	1NO	1N0	HW7D-L121010Q4 1 2 3				Circuit Protect
	Extended (bottom)	211710720	1NO-1NC	1NO-1NC	HW7D-L121111Q4 1 2 3		GR: Green (top)	Blank: Without	
			2N0	2NC	HW7D-L122002Q4 1 2 3	G	Red (bottom)	legend	Power
			1NO	1NC	HW7D-L211001Q4 1 2 3	PW	WB: White (top)	1: I / ON (top)	LED IIIu
	Flush (top)	24V AC/DC	1NO	1NO	HW7D-L211010Q4 1 2 3		Black (bottom)	0 / OFF (bottom)	041
	Flush (bottom)	211710/00	1NO-1NC	1NO-1NC	HW7D-L211111Q4 1 2 3				Controll
Interlock (*1)			2N0	2NC	HW7D-L212002Q4 1 2 3	ļ			Operato Interfac
			1NO	1NC	HW7D-L221001Q4 1 2 3				-

HW7D-L221010Q4 1 2 3

HW7D-L221111Q4 1 2 3

HW7D-L222002Q4 1 2 3

• LED lamp code: G (green), PW (pure white)

Flush (top)

Extended (bottom)

- Only W (white) lens is available.
- When replacing a G (green) LED, use an LSRD lamp and attachment lens. For details of the part no. see B-221.
- See B-185 for other operating voltage such as 100/110V AC and 200/220V AC.
- See B-185 for gold-plated silver contacts.
- Illuminated pushbutttons of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.

24V AC/DC

- See B-202 for top and bottom button contact mounting positions.
- *1) Interlock: Momentary operation, When one of the buttons is pressed, the other button cannot be operated, Do not operate top and bottom buttons at the same time. Operating the buttons at the same time may lead to malfunctions.

1N0

2N0

1NO-1NC 1NO-1NC

1N0

2NC

cy tches

oducts Proof

Blocks

Sockets

upplies

nination

Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

TW

Safety Products

Explosion Proof
Terminal Blocks

Relays & Sockets

Protectors

Power Supplies

LED Illumination

Controllers

Operator

Sensors

AUTO-ID


Flush Silhouette


ø30

Miniature Pilot Lights Dimensions All dimensions in mm.


Dual Pushbuttons

Without Pilot Light Terminal screws: M3.5, integrated terminal cover Flush (top), Flush (bottom)







Flush (top), Extended (bottom)






Flush (top), Extended (bottom) (with legend)







With Pilot Light Terminal screws: M3.5, integrated terminal cover Flush (top), Flush (bottom) (24V AC/DC)




Flush (top), Flush (bottom) (240V AC maximum)



Flush (top), Flush (bottom) (380V AC minimum)



Bottom View Without Pilot Light





2/4 contact blocks


YW

With Pilot Light

6, 12, 24V AC/DC







380V AC minimum

- See B-227 to B-228 for wiring.
- Mounting position of the dummy block may change according to the contact configuration of the top and bottom buttons.

Contact Arrangement Chart

	Contact		Contac	t Block	Тор В	utton	Bottom	Button
Top Button	Bottom Button	Contact Code	Mounting Position	Contact	Normal	Push	Normal	Push
1NO	1NO	1010	1	NO		•		
IIIIO	1110	1010	2	NO				•
1N0	1NC	1001	1	NO		•		
TINO	TNO TNO	1001	2	NC			•	
			1	NO		•		
1NO-1NC	1NO-1NC	1111	2	NO				•
TINO-TING	INO-INC	''''	3	NC	•			
			4	NC			•	
			1	NO		•		
2N0	2NC	2002	2	NC			•	
ZINU	2186	2002	3	NO		•		
			4	NC			•	

ullet Contact blocks ullet and ullet are actuated by the top button. Contact blocks ullet and ullet are actuated by the bottom button.

Contac	t Block	Top B	utton	Bottom	Button	← Button Position
Mounting Position	Contact	Normal	Push	Normal	Push	← Pushbutton Operation
1	NO		•			
2	NO				•	
3	NC	•				
4	NC			•		



With Pilot Light (Full Voltage Type)



With Pilot Light (Transformer Type)

Part No. Example HW7D-B121111GR

Contact Code

Contact Block Mounting Position



APEM

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers

Operator

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

TW

Knob Operator HW1S

Selector Switches (Knob Operator)

Package Quantity: 1

APEM SII

Switches & Pilot Lights

Emergency Stop Switches Enabling Switches Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit
Protectors

Power Supplies

LED Illumination

Controllers
Operator
Interfaces
Sensors

AUTO-ID

Flush Silhouette

ø22

Miniature

ø30

Pilot Lights

HW TW

YW

• Knob operator: white indicator on black body

- On the contact arrangement marked with \star in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.
- ullet For models with \dot{x} , contacts may overlap when the operator position is changed.

Dummy Block

- Other contact arrangements are also available. See B-211 to B-213.
- Selector switches with one or three contact blocks contain a dummy block.
- See B-186 for gold-plated silver contacts.
- Turn the operator to each position accurately.

Contact Block Mounting Position



Shape									>		
	Contact	Contact	Block	()pera	tor Po	sition	Maintained (90°)	Spring Return from Right (60°)	_	_
	Contact	Mounting Position	Contact	1	2			1 2	1 2		
	1NO	0	NO		•			- HW1S-2T10	HW1S-21T10	/	1
90°	(10)	2	_		_	ımy B	ock				/
2-position/ 60°	1NO-1NC	1	NO		•			HW1S-2T11	HW1S-21T11		/
2-position	(11)	2	NC	•							/
2 position	2N0	0	NO		•			HW1S-2T20	HW1S-21T20		/
	(20)	2	NO		•						/
		0	NO		•						/
	2NO-2NC	2	NC	•				HW1S-2T22	HW1S-21T22		/
	(22)	3	NO		•					/	/
		4	NC	•						/	
Contact				Maintained	Spring Return from Right	Spring Return from Left	Spring Return Two-way				
	Mounting Position	Contact	1	0	2						
		1 00141011									
	2N0	①	NO	•				LIWIE STOO	UW1C 21T20	LIWIE 22T20	LIMITE SSESS
	2N0 (20)		NO NO	•		•		HW1S-3T20	HW1S-31T20	HW1S-32T20	HW1S-33T20
		①		•		•					
	(20)	① ②	NO	•	-	•		HW1S-3T20 HW1S-3T02	HW1S-31T20 HW1S-31T02	HW1S-32T20 HW1S-32T02	HW1S-33T20 HW1S-33T02
	(20) 2NC	① ② ①	NO NC	•		•					
	(20) 2NC (02) 2NO-2NC	① ② ① ②	NO NC NC	_		•		HW1S-3T02	HW1S-31T02	HW1S-32T02	HW1S-33T02
	(20) 2NC (02)	① ② ① ② ①	NO NC NC NO	_							
4 5°	(20) 2NC (02) 2NO-2NC	① ② ① ② ① ②	NO NC NC NO	_				HW1S-3T02	HW1S-31T02	HW1S-32T02	HW1S-33T02
45° 3-position	(20) 2NC (02) 2NO-2NC	① ② ① ② ① ② ② ③	NO NC NC NO NO	_				HW1S-3T02	HW1S-31T02	HW1S-32T02	HW1S-33T02
	(20) 2NC (02) 2NO-2NC	① ② ① ① ② ② ③ ③ ④	NO NC NC NO NO NO NC	•				HW1S-3T02 HW1S-3T22N1	HW1S-31T02 HW1S-31T22N1	HW1S-32T02 HW1S-32T22N1	HW1S-33T02 HW1S-33T22N1
	2NC (02) 2NO-2NC (22N1)	① ② ① ② ② ③ ③ ④ ①	NO NC NC NO NO NO NC NC NC NC	•		•		HW1S-3T02	HW1S-31T02	HW1S-32T02	HW1S-33T02
	(20) 2NC (02) 2NO-2NC (22N1)	① ② ① ② ② ③ ③ ④ ① ②	NO NC NO NO NO NO NO NC NC NC NO NO NO	•		•		HW1S-3T02 HW1S-3T22N1	HW1S-31T02 HW1S-31T22N1	HW1S-32T02 HW1S-32T22N1	HW1S-33T02 HW1S-33T22N1
	(20) 2NC (02) 2NO-2NC (22N1)	① ② ① ① ② ③ ④ ① ② ③ ③	NO NC NO NO NO NC NC NC NC NC NC NO NO NO NO	•		•		HW1S-3T02 HW1S-3T22N1	HW1S-31T02 HW1S-31T22N1	HW1S-32T02 HW1S-32T22N1	HW1S-33T02 HW1S-33T22N1
	(20) 2NC (02) 2NO-2NC (22N1)	① ② ② ① ① ② ③ ④ ① ② ③ ③ ④ ④	NO NC NC NO NO NO NC NC NC NC NC NC NO NO NO NO NO NO	•		•		HW1S-3T02 HW1S-3T22N1 HW1S-3T40	HW1S-31T02 HW1S-31T22N1 HW1S-31T40	HW1S-32T02 HW1S-32T22N1 HW1S-32T40	HW1S-33T02 HW1S-33T22N1 HW1S-33T40
	(20) 2NC (02) 2NO-2NC (22N1) 4NO (40)	① ② ② ① ① ② ③ ③ ④ ① ② ③ ④ ④ ① ② ③ ④ ④ ② ② ③ ④ ④ ② ④ ④ ④ ④ ④ ④ ④ ④ ④ ④	NO NC NO NO NO NO NO NC NC NO	•		•		HW1S-3T02 HW1S-3T22N1	HW1S-31T02 HW1S-31T22N1	HW1S-32T02 HW1S-32T22N1	HW1S-33T02 HW1S-33T22N1
	(20) 2NC (02) 2NO-2NC (22N1) 4NO (40)	① ② ② ① ② ③ ③ ④ ① ② ③ ④ ① ② ② ② ② ④ ② ② ② ④ ④ ② ② ③ ④ ④ ② ② ③ ④ ④ ② ② ② ②	NO NC NO NO NO NO NO NC NO	•		•		HW1S-3T02 HW1S-3T22N1 HW1S-3T40	HW1S-31T02 HW1S-31T22N1 HW1S-31T40	HW1S-32T02 HW1S-32T22N1 HW1S-32T40	HW1S-33T02 HW1S-33T22N1 HW1S-33T40
	(20) 2NC (02) 2NO-2NC (22N1) 4NO (40) 4NC (04)	① ② ② ① ① ② ③ ③ ④ ① ② ③ ③ ④ ① ② ③ ③ ④ ④ ② ③ ③ ④ ④ ② ③ ③ ④ ④ ② ② ③ ③ ④ ① ② ② ③ ③ ③ ④ ② ② ③ ③ ③ ④ ② ② ③ ③ ④ ④ ② ② ④ ④ ② ② ④ ④ ② ② ④ ④ ② ② ④ ④ ② ② ④ ④ ④ ② ② ④ ④ ④ ② ② ④ ④ ④ ② ② ④ ④ ④ ② ② ④ ④ ④ ④ ② ② ④	NO NC NO	•		•		HW1S-3T02 HW1S-3T22N1 HW1S-3T40	HW1S-31T02 HW1S-31T22N1 HW1S-31T40	HW1S-32T02 HW1S-32T22N1 HW1S-32T40	HW1S-33T02 HW1S-33T22N1 HW1S-33T40
	(20) 2NC (02) 2NO-2NC (22N1) 4NO (40)	① ② ② ① ① ② ③ ③ ④ ① ② ③ ③ ④ ① ② ③ ③ ④ ④ ② ③ ③ ④ ④ ② ④ ④ ② ④ ④ ④ ② ④ ④ ④ ④	NO NC NO			•		HW1S-3T02 HW1S-3T22N1 HW1S-3T40	HW1S-31T02 HW1S-31T22N1 HW1S-31T40	HW1S-32T02 HW1S-32T22N1 HW1S-32T40	HW1S-33T02 HW1S-33T22N1 HW1S-33T40

Key Selector Switches (Pin Tumbler Key)

Package Quantity: 1

	No. of		Contact Block		Opera	ator Po	sition		Maintained	
Shape	Positions	Contact	Mounting Position	Contact	1	2		Cam Code	1 2	
Pin Tumbler Key		1NC	①	NC	•			•	HW1K-2PA01	
HW1K		(01)	2	-	Dur	nmy Bl	lock	_	IIWIR-ZFA01	
		1NO-1NC	①	NO		•			HW1K-2PA11	
		(11)	2	NC	•			-	HWTR-2FATT	
		2NC	①	NC	•				HW1K-2PA02	
		(02)	2	NC	•			-		
		2NO-1NC	①	NO		•				
	90°		2	NC	•				HW1K-2PA21	
		(21)	3	NO		•			IIW IN-ZFAZI	
	2-position		4	_	Dummy Block		lock			
1			①	NC	•					
The state of the s		3NC	2	NC	•				HW1K-2PA03	
		(03)	3	NC	•				11W 1N-2FA03	
			4		Dur	nmy Bl	lock			
			1	NO		•				
		2NO-2NC	2	NC	•				HW1K-2PA22	
(NC contact only)		(22)	3	NO		•			IIW IN-ZFAZZ	
(i.e solimation)			4	NC	•					

- Each selector key switch is supplied with two keys.
- 15 types of key numbers are available in addition to standard (500) key. See below for details.
- Spring-return type is also available. See below for details.
- Key retained position can be selected. See below for details.

Ordering Information

Example: HW1K - 2 J P A 01 - 501

Not specified: 500 (default key)
501-515: The key number is engraved on the key cylinder.

Key removat
A: Removat
Cam code: Blank or J
Operator position code:
2: 2-position, maintained
C: Removat

21: 2-position, spring return from right

Maintained (9	Maintained (90° 2-position)					
1 2	2 1	Spring return from right				
Cam code: blank	Cam code: J	Cam code: blank				

- For more contact arrangement, see B-211 to B-212.
- Key selector switches with one or three contact blocks contain a dummy block.
- See B-186 for gold-plated silver contacts.
- Turn the operator to each position accurately.

Contact Block Mounting Position



A: Removable/retained in all positions B: Removable in left theft only

C: Removable in right only

Key removable/retained positions

Key Retained Position

A (removable in all positions)

Cam code: blank

Key Retained Position										
A (removable in all positions)	B (removable in left only)	C (removable in right only)								
2 0	2 • • • • • • • • • • • • • • • • • • •	9 0								
	Cam code: J									

①②: Key removal position **①②**: Key retained position

Note: The key cannot be removed in a spring return position.

APEM

Switches &

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit
Protectors

Power Supplies

LED Illumination
Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

HW TW YW

APFM

Control Boxes

Emergency
Stop Switches
Enabling
Switches
Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Protectors

Power Supplies

LED Illumination

Controllers

Operator

Sensors

AUT0-ID

Key Selector Switches (Pin Tumbler Key)

Package Quantity: 1

	No. of	Conta	act Configuratio	n	Оре	rator Pos	ition	Cam	Maintained	
Shape	Positions	Contact Code	Mounting Position	Contact	1	0	2	Code	1 2	
Pin Tumbler Key		2NC	①	NC					HW1K-3PA02	
łW1K		(02)	2	NC					TIWTK-SI AUZ	
			①	NO	•				HW1K-3PA22N1	
		2NO-2NC (22N1)	2	NO			•			
	45° 3-position		3	NC				_		
			4	NC]		
		4NC (04)	①	NC						
			2	NC]	HW1K-3PA04	
			3	NC				<u> </u>	TIWTK-STA04	
			4	NC						
9			①	NO	•					
		2NO-1NC	2	NO			•] ,	LIMAK O IDAO4N4	
•		(21N1) ★☆	3	NC		•		J	HW1K-3JPA21N1	
		^~	4	_	Dι	ımmy Blo	ck			
			0	NC			•			
		4NC	2	NC	•			S	LIMAN SCOVOA	
(NC contact only)		(04)	3	NC			•) 8	HW1K-3SPA04	
(NO CONTEGET ONLY)		^	4	NC	•					

- On the contact arrangement marked with ★ in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.
- For models with ☆, contacts may overlap when the operator is changed.
- For contact block mounting position, see the figure on the right.
- Each key selector switch is supplied with two keys.
- 15 types of key numbers are available in addition to standard (500) key. See below for details.
- Spring-return type is also available. See below for details.
- Key retained position can be selected. See table below details.

Contact Block Mounting Position



Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

HW TW

YW

Ordering Information

Example: HW1K - 3 S P A 04 - 501

Not specified: 500 (default key)

501-515: The key number is engraved on the key cylinder.

Key remove A: Remove B: Remove C: Remove

31: 3-position, spring return from right 32: 3-position, spring return from left

33: 3-position, spring return two way

Maintained
(45° 3-position)

Spring Return (45° 3-position)

Maintained
Spring Return
from Right
from Left
Two-way

Cam code:
blank, J, or S

Spring Return
from Cam Code: blank

- For more contact arrangement, see B-211 to B-212.
- Key selector switches with one or three contact blocks contain a dummy block.
- See B-186 for gold-plated silver contacts.
- Turn the operator to each position accurately.

Key removal/retained positions

- A: Removable in all positions
- B: Removable in left and center
- C: Removable in right and center
- D: Removable in center only
- E: Removable in right and left
- G: Removable in left only
- H: Removable in right only

Note: The key cannot be removed in a spring return position.

Key Retained Position (45° 3-position)											
A (removable in all positions)	B (removable in left and center)	C (removable in right and center)	D (removable in center only)								
0 0 2	0 0 0	0 0 2	0 0 0								
E (removable in right and left only)	G (removable in left only)	H (removable in right only)									
	0 0	0 0 2									

● ● ②: Key retained position

Note: The key cannot be removed in a spring return position.

APFM

Control Boxes

Emergency Stop Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Power Supplies

LED Illumination

Controllers

Operator

Sensors

AUTO-ID

Flush Silhouette

Interfaces

Circuit

Protectors

Enabling Switches

Key Selector Switches (Disc Tumbler Key)

Disc Tumbler Key HW1K Package Quantity: 1

No. of **Positions** (NC contact only) Contact Configuration Operator Position Maintained (90°) Spring Return from Right (60°) Cam Code Mounting **Contact Code** Contact 2 Position 1 N0 1N0 HW1K-2A10 HW1K-21B10 (10)2 **Dummy Block** 1 NC • 1NC HW1K-21B01 HW1K-2A01 (01)2 **Dummy Block** 1 N0 1NO-1NC HW1K-2A11 HW1K-21B11 (11)NC • 2 1 N0 2N0 HW1K-2A20 HW1K-21B20 (20)2 N0 1 NC 2NC HW1K-2A02 HW1K-21B02 (02)NC • 2 90° 1 NO • 2-position/ 2 NC • 2NO-1NC HW1K-2A21 HW1K-21B21 2-position (21)3 NO 4 **Dummy Block** 1 NC 2 NC 3NC HW1K-2A03 HW1K-21B03 (03)3 NC 4 **Dummy Block** 1 NO

• Each key selector switch is supplied with two keys.

2NO-2NC

(22)

- 3 types of key numbers are available in addition to standard key.
- Key retained position can be selected. See table below for key retained positions.

2

3

4

NC

N0

NC

Contact Block Mounting Position

HW1K-21B22

ø30 Miniature

ø16


Pilot Lights

Pilot Lights

TW

YW

Ordering Information



Operator position code: 2: 2-position, maintained

21: 2-position, maintained 21: 2-position, spring return from right

		· ·
Maintained (9	Spring Return (60° 2-position)	
1 2	2 1	Spring Return from Right
Cam code: blank	Cam code: J	Cam code: blank

- For more contact arrangement, see B-211 to B-213.
- Key selector switches with one or three contact blocks contain a dummy block.
- See B-186 for gold-plated silver contacts.
- · Turn the operator to each position accurately.

A: Removable in all positions B: Removable in left only C: Removable in right only

Key Retained Position

HW1K-2A22

	ovable in ositions)	B (removable in left only)	C (removable in right only)							
•	©	⊕ •	Q 20							
	Cam code: blank									
	Key Removal Position									
	ovable in ositions)	B (removable in left only)	C (removable in right only)							
0		© 0	0							
	Cam code: J									

①②: Key removal position

• Wey retained position

Note: The key cannot be removed in a spring return position.

Key Selector Switches (Disc Tumbler Key)

Package Quantity: 1

APFM

Control Boxes Emergency Stop Switches Enabling Switches

Safety Products Explosion Proof

Terminal Blocks Relays & Sockets

Protectors

Power Supplies

LED Illumination

Controllers Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø30

Miniature

Pilot Lights

TW YW

Disc Tumbler Key HW1K No. of (NC contact only) Positions Operator Spring Return Maintained Spring Return Spring Return Contact Configuration Position from Right from Left Two-way Cam Mounting Code **Contact Code** Contact 0 2 Position 2N0 1 NO HW1K-3A20 HW1K-31B20 HW1K-32C20 HW1K-33D20 (20)2 N0 2NC 1 NC HW1K-3A02 HW1K-31B02 HW1K-32C02 HW1K-33D02 NC (02)2 1 NΟ 2NO-2NC 2 N0 HW1K-3A22N1 HW1K-31B22N1 HW1K-32C22N1 HW1K-33D22N1 (22N1)3 NC 4 NC ① NO 4N0 2 NO HW1K-3A40 HW1K-31B40 HW1K-32C40 HW1K-33D40 (40)3 NO 45° 4 N0 3-position 1 NC 4NC (2) NC HW1K-3A04 HW1K-31B04 HW1K-32C04 HW1K-33D04 (04)3 NC 4 NC 1 NC 4NC 2 NC S HW1K-3SA04 (04)3 NC •

• On the contact arrangement marked with 🛨 in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.

HW1K-3JA21N1

For models with ★, contacts may overlap when the operator is changed. Each key selector switch is supplied with two keys.

Dummy Block

J

• 3 types of key numbers are available in addition to standard key.

4

(I)

2

3

(4)

2NO-1NC

(21N1)

• Key retained position can be selected. See table below for key retained positions.

NC

N0

N0

NC

•

Contact Block Mounting Position

Ordering Information

Example: HW1K-35A04-1H Not specified: 231 (default key)
The key number is engraved on the key cylinder. 1H 2H ЗН Key removal/retained positions Cam code: Blank, J, or S

Operator position code:

- 3: 3-position, maintained
- 31: 3-position, spring return from right
- 32: 3-position, spring return from left
- 33: 3-position, spring return two way

Maintained (45° 3-position)	Spring Return (45° 3-position)									
Maintained	Spring Return from Right	Spring Return from Left	Spring Return Two-way							
1 0 2	1 0 2	1 0 2	1 0 2							
Cam code: blank, J, or S		Cam code: blank								

- For more contact arrangement, see B-211 to B-213.
- · Key selector switches with one or three contact blocks contain a dummy block.
- See B-186 for gold-plated silver contacts.
- Turn the operator to each position accurately.

- A: Removable in all positions
- E: Removable in right and left
- B: Removable in left and center C: Removable in right and center
- G: Removable in left only H: Removable in right only
- D: Removable in center only

Note: The key cannot be removed in a spring return position.

Key Retained Position											
A (removable in all positions)	B (removable in left and center)	C (removable in right and center)	D (removable in center only)								
0 0 2	0 0 0	0 0 2	0 0 0								
E (removable in right and left only)	G (removable in left only)	H (removable in right only)									
0 2	0 0	0 0									

⊕ ⊕ ②: Key removal position

Note: The key cannot be removed in a spring return position.

APEM

Control Boxes Emergency Stop Switches Enabling Switches Safety Products Explosion Proof Terminal Blocks Relays & Sockets Circuit Protectors Power Supplies LED Illumination Controllers Operator Interfaces Sensors AUTO-ID

Flush Silhouette

ø16

ø30
Miniature
Pilot Lights

TW

YW

LED

Selector Switches (Knob Operator)

Package Quantity: 1

												,.
No. of Positions	Knob Ope HW1F	rator										
	Contact Configuration				perat ositio		Operating	Maintained (90°)	Spring return from right (60°)			Color
	Contact Code	Mounting Position	Contact	1	2		Voltage	1 2	1 2	_	_	Code
	4110 4110	0	NO		•		24V AC/DC	HW1F-211Q4*	HW1F-2111Q4*			
90°	1NO-1NC (11)	2	NC	•			100/110V AC	HW1F-211H2*	HW1F-2111H2*			
2-position/	(11)						200/220V AC	HW1F-211M2*	HW1F-2111M2*			R
60°	0110	0	NO		•		24V AC/DC	HW1F-220Q4*	HW1F-2120Q4*			G
2-position	2N0 (20)	2	NO		•		100/110V AC	HW1F-220H2*	HW1F-2120H2*			Ϋ́
	(20)						200/220V AC	HW1F-220M2*	HW1F-2120M2*			A
		①	NO		•		24V AC/DC	HW1F-222Q4*	HW1F-2122Q4*			S PW
	2NO-2NC	2	NC	•			100/110V AC	HW1F-222H2*	HW1F-2122H2*			PVV
	(22)	3	NO		•		200/220V AC	HW1F-222M2*	HW1F-2122M2*			
		4	NC	•								
	Contact Configuration				perat ositio		Operating	Maintained	Spring return from right	Spring return from left	Spring Return Two-way	Color
	Contact Code	Mounting Position	Contact	1	0	2	Voltage	1 0 2	1 0 2		1 0 2	Code
	0110	0	NO	•			24V AC/DC	HW1F-320Q4*	HW1F-3120Q4*	HW1F-3220Q4*	HW1F-3320Q4*	
	2N0 (20)	2	NO			•	100/110V AC	HW1F-320H2*	HW1F-3120H2*	HW1F-3220H2*	HW1F-3320H2*	1
	(20)						200/220V AC	HW1F-320M2*	HW1F-3120M2*	HW1F-3220M2*	HW1F-3320M2*	1
	ONO	①	NC				24V AC/DC	HW1F-302Q4*	HW1F-3102Q4*	HW1F-3202Q4*	HW1F-3302Q4*	
	2NC (02)	2	NC				100/110V AC	HW1F-302H2*	HW1F-3102H2*	HW1F-3202H2*	HW1F-3302H2*	
	(02)						200/220V AC	HW1F-302M2*	HW1F-3102M2*	HW1F-3202M2*	HW1F-3302M2*	
45°		①	NO	•			24V AC/DC	HW1F-322N1Q4*	HW1F-3122N1Q4*	HW1F-3222N1Q4*	HW1F-3322N1Q4*	R
3-position	2NO-2NC	2	NO			•	100/110V AC	HW1F-322N1H2*	HW1F-3122N1H2*	HW1F-3222N1H2*	HW1F-3322N1H2*	G
	(22N1)	3	NC				200/220V AC	HW1F-322N1M2*	HW1F-3122N1M2*	HW1F-3222N1M2*	HW1F-3322N1M2*	Υ
		4	NC									A
		0	NO	•			24V AC/DC	HW1F-340Q4*	HW1F-3140Q4*	HW1F-3240Q4*	HW1F-3340Q4*	S
	4N0	2	NO			•	100/110V AC	HW1F-340H2*	HW1F-3140H2*	HW1F-3240H2*	HW1F-3340H2*	· "
	(40)	3	NO	•			200/220V AC	HW1F-340M2*	HW1F-3140M2*	HW1F-3240M2*	HW1F-3340M2*	
		4	NO			•						
		0	NC				24V AC/DC	HW1F-304Q4*	HW1F-3104Q4*	HW1F-3204Q4*	HW1F-3304Q4*	
	4NC					1	1400/4401/40	LUMBE OF ALIG.			LULIATE OCCULIO	1
		2	NC				100/110V AC	HW1F-304H2*	HW1F-3104H2*	HW1F-3204H2*	HW1F-3304H2*	-
	4NC (04)	3	NC NC			-	200/220V AC	HW1F-304H2* HW1F-304M2*	HW1F-3104H2* HW1F-3104M2*	HW1F-3204H2* HW1F-3204M2*	HW1F-3304H2* HW1F-3304M2*	

- $\bullet \ \, \text{Specify a color code in place of} * \ \, \text{in the Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)} \\$
- See B-186 for other operating voltage such as 6V AC/DC and 12V AC/DC.

NC

- Illuminated selector switches of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.
- See B-211 to B-213 for other contact arrangements.
- See B-186 for gold-plated silver contacts.
- Turn the operator to each position accurately.

Contact Block Mounting Position



IDEC

Lever Operator HW1F□L

APEM

Control Boxes

Emergency
Stop Switches
Enabling
Switches
Safety Products

Explosion Proof
Terminal Blocks
Relays & Sockets

Protectors
Power Supplies

LED Illumination

Controllers

Operator

Sensors AUTO-ID

Flush Silhouette

ø30 Miniature Pilot Lights

LED Selector Switches (Lever Operator)

Package Quantity: 1

No. of Positions



										•			
		Contact	Contac	t Block		pera ositi		Operating	Maintained (90°)	Spring Return from Right (60°)			Color
-		Code	Mounting Position	Contact	1	2		Voltage	1 2	12	_	_	Code
		4110 4110	0	NO		•		24V AC/DC	HW1F-2L11Q4*	HW1F-21L11Q4*			
	90°	1NO-1NC (11)	2	NC	•			100/110V AC	HW1F-2L11H2*	HW1F-21L11H2*			
-	2-position/	(11)						200/220V AC	HW1F-2L11M2*	HW1F-21L11M2*			
.	60°	0110	0	NO		•		24V AC/DC	HW1F-2L20Q4*	HW1F-21L20Q4*			R G
	2-position	2N0 (20)	2	NO				100/110V AC	HW1F-2L20H2*	HW1F-21L20H2*] /		Ϋ́
-		(20)						200/220V AC	HW1F-2L20M2*	HW1F-21L20M2*			A
			0	NO		•		24V AC/DC	HW1F-2L22Q4*	HW1F-21L22Q4*			S PW
	2NO-21	2NO-2NC	2	NC	•			100/110V AC	HW1F-2L22H2*	HW1F-21L22H2*			
-		(22)	3	NO		•		200/220V AC	HW1F-2L22M2*	HW1F-21L22M2*			
.			4	NC	•								
_		Contact Block				pera			Maintained	Spring Return	Spring Return	Spring Return	
		Contact	Blo	ck	P	ositi	on	Operating	0	from Right	from Left	Two-way	Color
		Code	Mounting Position	Contact	1	0	2	Voltage	1 2	1 0 2	2	1 2	Code
		0110	0	NO	•			24V AC/DC	HW1F-3L20Q4*	HW1F-31L20Q4*	HW1F-32L20Q4*	HW1F-33L20Q4*	
-		2N0 (20)	2	NO			•	100/110V AC	HW1F-3L20H2*	HW1F-31L20H2*	HW1F-32L20H2*	HW1F-33L20H2*	
-		(20)						200/220V AC	HW1F-3L20M2*	HW1F-31L20M2*	HW1F-32L20M2*	HW1F-33L20M2*	
		0110	0	NC				24V AC/DC	HW1F-3L02Q4*	HW1F-31L02Q4*	HW1F-32L02Q4*	HW1F-33L02Q4*	
		2NC (02)	2	NC		-		100/110V AC	HW1F-3L02H2*	HW1F-31L02H2*	HW1F-32L02H2*	HW1F-33L02H2*	
-		(02)						200/220V AC	HW1F-3L02M2*	HW1F-31L02M2*	HW1F-32L02M2*	HW1F-33L02M2*	
-	45° 3-position		0	NO	•			24V AC/DC	HW1F-3L22N1Q4*	HW1F-31L22N1Q4*	HW1F-32L22N1Q4*	HW1F-33L22N1Q4*	R
	3-position	2NO-2NC	2	NO			•	100/110V AC	HW1F-3L22N1H2*	HW1F-31L22N1H2*	HW1F-32L22N1H2*	HW1F-33L22N1H2*	Ğ
		(22N1)	3	NC				200/220V AC	HW1F-3L22N1M2*	HW1F-31L22N1M2*	HW1F-32L22N1M2*	HW1F-33L22N1M2*	Υ
	(221)	l ` '											A
u			4	NC	_								
					•			24V AC/DC	HW1F-3L40Q4*	HW1F-31L40Q4*	HW1F-32L40Q4*	HW1F-33L40Q4*	S
		4N0	4	NC	•		•	24V AC/DC 100/110V AC	HW1F-3L40Q4* HW1F-3L40H2*	HW1F-31L40Q4* HW1F-31L40H2*	HW1F-32L40Q4* HW1F-32L40H2*	HW1F-33L40Q4* HW1F-33L40H2*	
-		4NO (40)	4 0 2 3	NC NO NO	•		•						S
			412	NC NO NO NO			•	100/110V AC 200/220V AC	HW1F-3L40H2* HW1F-3L40M2*	HW1F-31L40H2*	HW1F-32L40H2* HW1F-32L40M2*	HW1F-33L40H2* HW1F-33L40M2*	S
-			402340	NC NO NO NO NO				100/110V AC 200/220V AC 24V AC/DC	HW1F-3L40H2* HW1F-3L40M2* HW1F-3L04Q4*	HW1F-31L40H2* HW1F-31L40M2* HW1F-31L04Q4*	HW1F-32L40H2* HW1F-32L40M2* HW1F-32L04Q4*	HW1F-33L40H2* HW1F-33L40M2* HW1F-33L04Q4*	S
		(40) 4NC	(a) (b) (c) (c) (d) (d) (d) (d) (d) (d) (d) (d) (d) (d	NC NO NO NO NO NO NC				100/110V AC 200/220V AC 24V AC/DC 100/110V AC	HW1F-3L40H2* HW1F-3L40M2* HW1F-3L04Q4* HW1F-3L04H2*	HW1F-31L40H2* HW1F-31L40M2* HW1F-31L04Q4* HW1F-31L04H2*	HW1F-32L40H2* HW1F-32L40M2* HW1F-32L04Q4* HW1F-32L04H2*	HW1F-33L40H2* HW1F-33L40M2* HW1F-33L04Q4* HW1F-33L04H2*	S
		(40)	402340	NC NO NO NO NO				100/110V AC 200/220V AC 24V AC/DC	HW1F-3L40H2* HW1F-3L40M2* HW1F-3L04Q4*	HW1F-31L40H2* HW1F-31L40M2* HW1F-31L04Q4*	HW1F-32L40H2* HW1F-32L40M2* HW1F-32L04Q4*	HW1F-33L40H2* HW1F-33L40M2* HW1F-33L04Q4*	S

- Specify a color code in place of * in the Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)
- \bullet See B-186 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.
- Illuminated selector switches of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.
- See B-211 to B-213 for other contact arrangements.
- See B-186 for gold-plated silver contacts.
- Turn the operator to each position accurately.

Contact Block Mounting Position



Illuminated (full voltage)

Illuminated (transformer)

APEM

Control Boxes

Emergency Stop Switches

Relays & Sockets Circuit

Power Supplies LED Illumination Controllers Operator Sensors AUTO-ID


Protectors

Enabling Switches Safety Products **Explosion Proof** Terminal Blocks

Dimensions All dimensions in mm.

Selector Switch (Knob Operator)


Terminal Screws M3.5 Integrated Terminal Cover



Key Selector Switch (Knob Operator)

Disc Tumbler Type

Terminal Screws M3.5 Integrated Terminal Cover



Illuminated Selector Switch (Knob Operator)


Terminal Screws M3.5 Integrated Terminal Cover

6, 12, 24V AC/DC, Without LED lamp

49.4 (1 or 2 blocks)

100/110V AC, 200/220V AC (240V AC maximum)

110V DC, 380V AC minimum




Illuminated Selector Switch (Lever Operator)

Terminal Screws M3.5 Integrated Terminal Cover

6, 12, 24V AC/DC, Without LED lamp


100/110V AC, 200/220V AC (240V AC maximum)

110V DC, 380V AC minimum




Bottom View

Non-illuminated







3 contact blocks


3 contact blocks


2/4 contact blocks


Illuminated

6, 12, 24V AC/DC, Without LED lamp

1 contact block









Dummy Block

2/4 contact blocks

100/110V AC 200/220V AC (240V AC maximum)





110V DC,

ullet For DC-DC Converter types, terminal X1 is \oplus , X2 is \ominus .

IDEC

ø30 Miniature

Pilot Lights

Flush Silhouette

TW YW

Selector Switch Contact Arrangement

90° 2-position (Spring Return 60° 2-position) <Maintained/Spring Return from Right>

- i	Operator Operation and Circuit Availability												
#													
ilot Lights					Mainta	ined	Spring	Return	from Right				
nts					1	2							
		Contact	Block			/							
	0			Vnoh/			Vnoh/						
	Contact			Knob/ Lever	Key	Illuminated	Knob/ Lever	Key	Illuminated	Cam			
APEM	Code			Level			revei			Code			
Switches &					Opera			Opera	tor				
Pilot Lights		Mounting	C11		Posit	ion							
Control Boxes		Position	Contact	1		2	1		2	ĺ			
Emergency				(B)		\mathscr{D}							
Stop Switches	1NO	1	NO			$\overline{\bullet}$			$\overline{\bullet}$				
Enabling	(10)	2	_	D	ıımmv	Block	D	ummy	Block	-			
Switches	1NC	1	NC	•	<u> </u>	<u> </u>	•	<u> </u>	5.00.1				
Safety Products	(01)	2	_	D	ummv	Block	D	ummy	Block				
	1NO-1NC	1	NO			•			•				
Explosion Proof	(11)	2	NC	•			•	\top		-			
Terminal Blocks	2N0	1	NO			•		\top	•				
	(20)	2	NO			•		\top	•				
Relays & Sockets	2NC	1	NC	•			•	\top					
Circuit	(02)	2	NC	•			•			-			
Protectors		1)	NO			•			•				
	2NO-2NC	2	NC	•			•						
Power Supplies	(22)	3	NO			•			•	-			
LED Illumination		4	NC	•			•			1 1			
		1	NC	•			•						
Controllers	3NO-1NC	2	NO			•			•	l l			
Operator	(31N1)	3	NO			•			•				
Interfaces		4	NO			•			<u> </u>				
Sensors		1	NO			•			•				
	4N0	2	NO			•			<u> </u>	_			
AUTO-ID	(40)	3	NO			•			•				
		4	NO			•			<u> </u>				
	1NO-1NC ★	1	EM					=		_			
	(7S)	2	LB										
Flush Silhouette		1	NC	•			•						
——————————————————————————————————————	3NC	2	NC	•			•			_			
ø16	(03)	3	NC	•			•						
		4	 _	D	ummy	Block	D	ummy		igsquare			
ø22		1)	NO NO			•							
ø30	2NO-1NC	2	NC	•		_	•	+		_			
	(21)	3	NO			Disale			Disale				
Miniature		4		L D	ummy	Block		ummy	RIOCK				

Pilot Lights 90° 2-position Cam Reversed (Maintained)

	Contact Block		Operator Operation and Circuit Availability				
Contact Code			Maintained				
			2 1				
			Knob/Key/Illuminated				
	Mounting Position	Contact	Operator Position				
			2	1			
			(g)				
2NC	1	NC		•] ,]		
(02)	2	NC		•	J		
	1	NC		•			
3NC (03)	2	NC		•	J		
	3	NC		•			
	4	_	Dummy Block				

[•] On the contact arrangement marked with ★ in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.

45° 3-position

<Maintained>

Contact Code	Contact Block		Operator Position			Circuit Availability			
	Mounting Position	Contact	1	0	2	Knob/ Lever	Key	Illuminated	Cam Code
1NO-1NC ★	1	NC		•		×	×	×	J
(11N1) ☆	2	NO			•	^	^	_ ^ _	J
*	1	NC			•				
4NC	2	NC	•			×	×	×	S
(04)	3	NC			•	^	^	^	ა
	4	NC	•						
2NO-1NC ☆	1	NO	•			×	×	×	J
2NU-1NC ☆ (21N1)	2	NO			•				
	3	NC		•					
	4	_	Dummy Block						

45° 3-position

< Maintained/Spring Return from Right/Spring Return from Left/Spring Return Two-way>

Contact Code	Contact Block		Operator Position			Circuit Availability			
	Mounting Position	Contact	1	0	2	Knob/ Lever	Key	Illuminated	Cam Code
1NO-1NC (11)	1 2	NO NC	•			×	×	×	_
1NO-1NC (11N1)	1 2	NC NO			•	×	×	×	_
2N0 (20)	1 2	NO NO	•		•	×	×	×	_
2NC (02)	① ②	NC NC				×	×	×	_
2NO-2NC (22N1)	① ② ③ ④	NO NO NC NC			•	×	×	×	
2NO-2NC (22N2)	① ② ③ ④	NC NO NC NO			•	×	×	×	-
4NO (40)	① ② ③ ④	NO NO NO	•		•	×	×	×	
4NC (04)	① ② ③ ④	NC NC NC				×	×	×	_

• On the contact arrangement marked with ★ in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.

APEM

Switches &

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

. ..

Circuit Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30

22

Miniature

Pilot Lights

W

TW

45° 4-position, except for Key Selector, Illuminated Selector

				Operator	Position		Maintained	
Contact Code	Contac	t Block			3	4	1 3	Cam Code
	Mounting Position	Contact					Knob Operator	
★	1	NO	•					
1NO-2NC	2	NC		•			×	
(12)	3	NC			•		^	
, ,	4	_		Dumm				
*	1	LB						
1NO-3NC ☆	2	NC		•			×	
(13N6)	3	NC			•		^	_
	4	NO				•		
★☆	1	NO	•					
2NO-2NC	2	NC		•			×	
(22N3)	3	NC			•		^	
, ,	4	NO				•		

Pilot Lights Control Boxes Emergency Stop Switches Enabling Switches Safety Products Explosion Proof

Relays & Sockets

Protectors
Power Supplies
LED Illumination
Controllers
Operator
Interfaces
Sensors

Terminal Blocks

30° 5-position, except for Key Selector, Illuminated Selector

				Ор	erator Posit	ion		Maintained	
Contact Code	Contac	t Block	1	2	3	4	5	1 2 3 4 5	Cam Code
	Mounting Position	Contact			W)	(2)	Ø	Knob Operator	
*	1	NO	•						
2NO-2NC ☆	2	NC		•				×	
(22N3)	3	NC				•		^	-
, ,	4	NO					•		

- On the contact arrangement marked with ★ in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.
- \bullet For models with $\not \simeq$, contacts may overlap when the operator is changed.

Flush Silhouette Part No. Development


ø16 EX ø22 I

AUTO-ID

Miniature


Pilot Lights

Example 1: Knob Operator 2-position




Example 3: Illuminated Selector 3-position





- 31: 3-position/spring return from right32: 3-position/spring return from left
 - 33: 3-position/spring return two-way

Example 2: Key Selector 3-position



- 31: 3-position/spring return from right 32: 3-position/spring return from left
- 32: 3-position/spring return from left 33: 3-position/spring return two-way

Contact Block Mounting Position





Illuminated Selector (Transformer)



Non-illuminated Selector


(Full Voltage)

Package Quantity: 1

Shape	Circuit	Contact	Contac	t Block			(RIng Operator	Button Color Code	lot Lights
	Category	Code	Mounting Position	Contact	Normal	Depressed	Normal	Depressed	Part No.	Color Code	S
HW1R		1NO-1NC	1	NO		•		•	HW1R-2A11*		
		(11)	2	NC	•				IIW IN-ZATI*		APEM
		2N0 (20)	1	NO		•		•	HW1R-2A20*		Switches
	A		2	NO		•					Pilot Light
	, ,		1	NO		•		•	HW1R-2A22* HW1R-2D20* HW1R-2D22N1*		Control Bo
		2NO-2NC	2	NC	•						Emergenc
		(22)	3	NO	_	•		•			Stop Swite Enabling
			4	NC	•						Switches
		2N0 (20) D 2N0-2NC (22N1)	1	NO		•					Safety Pro
			2	NO NO				•			
	D		① ②	NO NO		•					Explosion
			3	NC NC	•					B G - R Y S W	Terminal I
			4	NC							Relays & S
	E	2NO-2NC (22N1)	1	NO		•			- HW1R-2E22N1*		Circuit
			2	NO				•			Protectors
			3	NC							Power Su
			4	NC							
		★ ☆	1	NO				•]	LED Illumi
	F	2NO-2NC	2	NO		•			HW1R-2F22N1*		Controllers
		(22N1)	3	NC			•		ΠWIN=ZFZZNI↑		Operator
			4	NC	•						Interfaces
		2NO-2NC (22N2)	1	NC			•				Sensors
	N	2NO-2NC	2	NO		•		•	HW1R-2N22N2*		AUTO-ID
		(22N2)		NC			•		THE LITERAL		
			4	NO		•		•		_	
			1	NO		•	•				
	Т	2NO-2NC	2	NO		•	•	Blocked	HW1R-2T22N1*		Flush Silho
		(22N1)	3	NC	•						
			4	NC	•						ø16

- Specify a button color code in place of * in the Part No. B (black), G (green), R (red), Y (yellow), S (blue), W (white)
- . When operating the pushbutton selector, do not turn the operator ring or the lock lever while the button is depressed. Otherwise the pushbutton selector may be damaged.
- On the contact arrangement marked page with * in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.
- \bullet For models with $\not \simeq$, contacts may overlap when the operator is changed.

Contact Block Mounting Position



• See B-210 for the bottom view.



		Le	ft	Rig	ht	← Ring Position
Mounting Position	Contact	Normal	Push	Normal	Push	← Button
1	NO				•	
2	NO		•			
3	NC			•		
4	NC	•				

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Operator Interfaces

Flush Silhouette

ø30

Miniature

Pilot Lights

TW

Circuit

Protectors
Power Supplies

Controllers

Operator Interfaces

Sensors

AUTO-ID

LED Illumination

Control Boxes

Emergency
Stop Switches
Enabling
Switches
Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Mono-Lever Switches

Package Quantity: 1

	Shape	Positions	Part No. (Ordering No.)			
HW1M			HW1M-1010-20			
Standard Lever			HW1M-2020-20			
		2-position	HW1M-0101-20			
		2-position	HW1M-0202-20			
			HW1M-0101-40			
			HW1M-0202-40			
		4	HW1M-1111-22N9			
		4-position	HW1M-2222-22N9			
HW1M-L			HW1M-L1010-20			
Interlocking Lever			HW1M-L2020-20			
		2-position	HW1M-L0101-20			
	766	2-position	HW1M-L0202-20			
			HW1M-L0101-40			
			HW1M-L0202-40			
		4 nosition	HW1M-L1111-22N9			
		4-position	HW1M-L2222-22N9			

• On all mono-lever switches, the rated current (load switching current) is reduced to a half of the rated current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.

Contact Arrangement Chart

2-position (Right/Left)

Contact Lever Operator Block Position Contact Code Mounting Position Contact Left Center Right 1 NO 20 2 NO 1 NO • 2 NO • 40 3 NO • 4 NO

2-position (Up/Down)

Contact	Cont B i o		Lev	er Opera Position	itor			
Code	Mounting Position	Contact	Left	Center	Right			
20	1	NO	•					
20	2	NO			•			
	1	NO	•					
40	2	NO			•			
40	3	NO	Left Center Right Output Out					
	4	NO			•			

4-position

	Contact	Cont Blo			Lever C	perator l	Position			
	Code	Mounting Position	Contact	Down	Left	Center	Up	Right		
ı		1	NC					•		
	22N9	2	NC	•						
ı	22119	3	NO		•					
		4	NO				•			

Flush Silhouette


ø22 ø30

Miniature

Pilot Lights

TW

Part No. Development



The lever operator of the interlocking type HW1M-L is locked only in the center position.
 Pull on the interlocking lever before operating the lever up/down/right/left.


Contact Block Mounting Position and Lever Operation Position




All dimensions in mm.

Pull on the interlocking lever before operating the lever up/down/right/left.

Standard Lever Interlocking Lever





Terminal Screws M3.5 Integrated Terminal Cover

• See B-210 for the bottom view.

Dimensions

Nameplates

Package Quantity: 1

Description	Legend	Material	Part No.	Ordering No.	Package Quantity	Dimensions (mm)
HWAM	Order marking plate	Plastic (black)	HWAM	HWAM	1	HWNP-□ marking plate (sold separately) is necessary. 29
HVVAIVI	(round) separately.	Flasiic (Diack)	HWAW	HWAMPN10	10	8 814.9
HWAQ	Order marking plate	HWAQ 1 29 (Marking Plat		(·····································		
пwaq	(square) separately.	Plastic (black)	HWAQ	HWAQPN10	10	R14.9 R15.9 R1
HWAS			HWAS-0	HWAS-0	1	1.6 0.9
HWAS	Blank	Plastic (black)		HWAS-0PN10	10	

[•] Nameplates cannot be used on HW series control stations (HW1X).

Marking Plates for HWAM/HWAQ

	Description	Material	Part No.	Ordering No.	Package Quantity	Dimensions (mm)
	HWNP	Aluminum (black)	HWNP-□	HWNP-□	1	White legend on black background. Engraving area: W25×H7
		Thickness = 1.0mm	nwnr-⊔	HWNP-□PN10	10	≃ <u>1</u>

 $[\]bullet$ Specify a legend code in place of \square in the Ordering No.

Legends

Code	Legend
0	(blank)
1	ON
2	0FF
3	START
4	STOP STOP
31	OFF-ON
35	HAND-AUTO
53	HAND-OFF-AUTO

[•] See B-226 for how to install nameplates/marking plates, and how to remove marking plates.

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers Operator

Interfaces
Sensors

AUTO-ID

Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

TW

Accessories All dimensions in mm.

When ordering, specify the Ordering No.

ᅙ			when			when ordering, specify the Ordering No.	
lot Lights		Shape	Material	Part No.	Ordering No.	Package Quantity	Dimensions (mm)
ន់		Locking Ring Wrench					Used to tighten the locking ring when installing the HW switch onto a panel.
APEM Switches & Pilot Lights			Metal (brass) (weight: approx. 150g)	MW9Z-T1	MW9Z-T1	1	110
Control Boxes							
Emergency Stop Switches Enabling		Lamp Holder Tool					 Used to install and remove the LED lamps. See B-223 to B-224 for how to install. (A): BA9S
Switches Safety Products	Tool	B	Nitrile rubber (black)	OR-55	OR-55	1	0R-55
Explosion Proof							59
Terminal Blocks Relays & Sockets		Contact Block Removal Tool					 Used to remove the contact block and transformer, and also to install/remove the pilot light and illuminated pushbutton lens. See B-224.
Circuit Protectors			Zinc-plated metal Nitril rubber	TW-KC1	TW-KC1	1	130
Power Supplies LED Illumination							
Controllers							8
Operator Interfaces	Anti-rotation Ring						Used to prevent the operator from turning. Generally
Sensors							used when using no nameplates on selector switches and pushbutton selectors.
AUTO-ID			Ring: polyamide Gasket: nitril rubber		HW9Z-RLPN10	10	022 TOP
Flush Silhouette	Rub	ber Mounting Hole Plug					Used to plug the unused ø22.2 mm mounting holes.
ø16						5	Degree of protection: IP65 (round hole) IP40 (with anti-rotation function)
ø22 ø30	(Nitril rubber (black) 0B-31		OB-31PN05		029
Miniature							\$\frac{1}{25}\$
Pilot Lights	Rub	ber Mounting Hole Plug	Plug: chrome-plated zinc diecast Locking ring:	LW9Z-BM	LW9Z-BM	1	Used to plug the unused ø22.2 mm mounting holes. Degree of protection: IP66 (round hole)
HW			polyamide Gasket: nitril rubber	21102 5111	ENGE BIII	,	Gasket Locking Ring
			dadiot. III i rabboi				Panel Thickness 0.8 to 6
	Met	allic Mounting Hole Plug					• Used to plug the unused ø22.2 mm mounting holes. Degree of protection: IP65 Tightening torque: 2.0 N·m
			Polyamide	LW9Z-BP1	LW9Z-BP1	1	Panel Thickness 0.8 to 6 Rubber Gasket Locking Ring M22 P: 1
	Barr	ier	Polyamide	HW-VU1	HW-VU1PN10	10	Used to prevent contact between adjacent lead wires when units are mounted closely (see B-227 for details). Barriers should always be used in close mounting.

Accessories All dimensions in mm.

When ordering, specify the Ordering No.

						When ordering, specify the Ordering No.	
Shape		Material	Part No.	Ordering No.	Package Quantity	Dimensions (mm)	Pilot Lights
Switch Guard	Spring Return	Guard: polyacetal Cover:	HW9Z-K1	HW9Z-K1	1	Used to prevent inadvertent operation for flush pushbuttons and illuminated pushbuttons. IP65 Maintained type stops at 90° and 180°. 31 min. Panel Thickness 0.8 to 5	APEM Switches & Pilot Lights Control Boxes
	Maintained	polyarylate Gasket: nitril rubber	HW9Z-K11	HW9Z-K11	1	0.8 to 5 2 15 15 15 15 15 15 15 15 15 15 15 15 15	Emergency Stop Switches Enabling Switches Safety Products
Button Clear Boot	For flush pushbuttons	Rubber	00-31	0C-31	1	Used to cover and protect pushbuttons where units are subject to watersplash. Not suitable for outdoor use or where the units are	Terminal Blocks Relays & Sockets
	For extended pushbuttons	(EPDM)	0C-32	0C-32	1	subject to oil splash. • Cannot be used with nameplates HWAM, HWAQ, HWAS, or HWAV. 18 (0C-31) 22 (0C-32)	Circuit Protectors Power Supplies
Padlock Cover		Polyarylate (gasket: nitryl rubber)	HW9Z-KL1	HW9Z-KL1	1	Used to protect pushbuttons, illuminated pushbuttons, selector switches, and key selector switches. Panel Thickness 0.8 to 3.2 Rubber Gasket 0.5t Key hole ø8 29.5 Rubber Gasket 0.5t Rubber Gasket 0.5t	Controllers Operator Interfaces Sensors AUTO-ID
Rubber Boot for Dual Push Switches	nbutton	Clear Silicon Rubber	HW9Z-D7D	HW9Z-D7D	1	• IP65 33 22.5	e30 Miniature Pilot Lights
Ring Adapter)	Nitryl rubber	HW9Z-A25	HW9Z-A25PN05	5	Used to install the HW series units into ø25 mm mounting holes. IP65 Cannot be used with anti-rotation, nameplate, and rubber boot for dual pushbutton switches. Mounting panel thickness: 1.2 to 6.0 mm See B-225 for details.	HW TW YW
Ring Adapter		Gasket: polyamide Washer: metal (brass)	HW9Z-A30	HW9Z-A30PN02	2	Used to install the HW series units (round type) into ø30 mm mounting holes (except for HW1P-5, HW1E, HW1B-M5/V5, HW7D, and HW1Z). IP65 Cannot be used with anti-rotation ring, nameplate, full-shroud illuminated pushbuttons, pushbutton selectors, and mono-lever switches. Mounting panel thickness: 1.6 to 4.0 mm	
Ring Adapter		Gasket: rubber Washer: metal		HW9Z-A30EPN02	2	Used to install jumbo dome pilot light HW1P-5Q units into ø30 mm mounting holes. IP65	

Control Boxes Emergency Stop Switches Enabling Switches Safety Products Explosion Proof Terminal Blocks Relays & Sockets

Protectors Power Supplies LED Illumination Controllers Operator

Sensors

AUTO-ID

Flush Silhouette

ø30 Miniature Pilot Lights

> TW YW

Maintenance Parts

All dimensions in mm.

					When ordering, specify the Ordering No.	
Shape	Material	Part No.	Ordering No.	Package Quantity	Remarks	
Contact Block	NO contact	HW-U10	HW-U10	1	Housing color: blue/Push rod color: green	
HW-U	NO contact	HW-U10-MAU	HW-U10-MAU	'	MAU has gold contacts	
	NC contact	HW-U01	HW-U01	1	Housing color: reddish purple/Push rod color: red	
	NO COMaci	HW-U01-MAU	HW-U01-MAU	'	MAU has gold contacts	
	EM (early make)	HW-U10R	HW-U10R	1	Housing color: blue/Push rod color: black	
	contact	HW-U10R-MAU	HW-U10R-MAU	'	MAU has gold contacts	
	LB (late break)	HW-U01R	HW-U01R	1	Housing color: reddish purple/Push rod color: white	
Weight: 11g (approx.)	contact	HW-U01R-MAU	HW-U01R-MAU	'	MAU has gold contacts	
Dummy Block Weight: 3.5g (approx.)	Polyamide	HW-DB	HW-DBPN10	10	For HW-U contact blocks Used when the number of contact blocks and full voltage adapters is odd number.	
Full Voltage Adapter for Illuminated (*1) Weight: 12g (approx.)	Polyamide	HW-GA1N	HW-GA1NPN02	2	Applicable model: Illuminated pushbuttons Illuminated selector switches Applicable load (LED lamp) LSRD-6, LSTD-6 (6V AC/DC) LSRD-1, LSTD-1 (12V AC/DC) LSRD-2, LSTD-2 (24V AC/DC)	
Transformer Unit (*1)	100/110V AC	HW-T16	HW-T16	1	Applicable model: Illuminated pushbuttons Illuminated selector switches	
Weight: 12g (approx.)	200/220V AC	HW-T26	HW-T26	1	Applicable load (LED lamp) LSRD-6, LSTD-6 (6V AC/DC)	

^{*1)} Maintenance parts are used for maintenance parts only. Do not use these parts for expansion or remodeling purpose.

						When ordering, specify the Ordering No.
Sh	Shape		Part No.	Ordering No.	Package Quantity	
Lens ① ②	①Round flush	Polyarylate ø23.5 H4.2	HW9Z-L11*-K	HW9Z-L11*-KPN05	5	
	②Square flush	Polyarylate ø24.6 H4	HW9Z-L21*-K	HW9Z-L21*-KPN05	5	R (red), G (green), Y (yellow), A (amber), C (clear), S (blue) (*2)
(a)	③Round extended	Polyarylate ø23.3 H10	HW9Z-L12*-K	HW9Z-L12*-KPN05	5	
5	⊕ø29 mushroom	AS, marking type ø29 H12.7	ALW31LD-*-K	ALW31LD-*-KPN02	2	R (red), G (green),Y (yellow), A (amber), S (blue), C (clear) (*2)
(S)	®ø40 mushroom	AS, marking type ø40 H12.7	ALW41LD-*-K	ALW41LD-*-K	1	R (red), G (green), Y (yellow), A (amber), S (blue), C (clear) (*2)
0	©Jumbo dome	Polycarbonate ø66 H50	HW1A-P5*	HW1A-P5*	1	R (red), G (green), Y (yellow), A (amber), W (white), S (blue)
	⑦Dome for pilot light	AS ø23.5 H15.1	HW1A-P2*-K	HW1A-P2*-KPN05	5	R (red), G (green), Y (yellow), A (amber), W (white), S (blue) (*3)
Button ① ②	①Round flush with round or square bezel	Polyacetal ø23.6 H3	HW1A-B1*	HW1A-B1*PN05	5	
	②Round extended with round or square bezel	Polyacetal ø23.6 H9.2	HW1A-B2*	HW1A-B2*PN05	5	
3	3Square flush	Polyacetal □24.8 H3	HW2A-B1*	HW2A-B1*PN05	5	Use ① for pushbutton selectors.
5	Square extended	Polyacetal □24.5 H9.2	HW2A-B2*	HW2A-B2*PN05	5	B (black), G (green), R (red), Y (yellow), S (blue), W (white)
6	⑤ø29 mushroom	Polyacetal ø29 H12.7(M18P1.0)	HW1A-B3*	HW1A-B3*PN02	2	
	©ø40 mushroom	Polyacetal ø40 H12.7(M18P1.0)	HW1A-B4*	HW1A-B4*PN02	2	

^{*2)} Use C (clear) lens for PW (pure white) illumination.

^{*3)} Use W (white) lens for PW (pure white) illumination.

Maintenance Parts All dimens

When ordering, specify the Ordering No.

							When ordering, specify the Ordering No.	[라
	Shape		Material/Dimensions	Part No.	Ordering No.	Package Quantity	Remarks	ilot Lights
	Round flush		Acrylic ø21.5 Thickness = 1	HW9Z-P11	HW9Z-P11PN05	5	White See B-225 for dimensions and engraving area.	ts
ı Plate	Round extended		Acrylic ø21.3 Thickness = 6.5	HW9Z-P12	HW9Z-P12PN05	5	onyraviny arda.	APEM Switches &
Marking Plate	Square flush		Acrylic 22.7 Thickness = 1	HW9Z-P21	HW9Z-P21PN05	5		Pilot Lights Control Boxes
	ø29/40 mm mushroom		Acrylic ø15.7 H3.4	ALW3B	ALW3BPN05	5		Emergency Stop Switches Enabling
	ator Knob for Illumina	ated					Specify a color code in place of *.	Switches Safety Products
Sele	ctor Switch			HW9Z-FDY*-K	HW9Z-FDY*-K	1	R (red), G (green), Y (yellow), A (amber), W (white), S (blue)	Explosion Proof
							Use W (white) knob/lever for pure white illumination.	Terminal Blocks
	rator Lever for Illumina	ated	AS resin				munnitudion.	Relays & Sockets
Sele	ctor Switch			HW9Z-FDL*-K	HW9Z-FDL*-K	1		Circuit Protectors
	100							Power Supplies
	e Key Tumber Key)	\cap						LED Illumination
ופוטו	, rambor Roy)		Metal (nickel-plated brass)	HW9Z-SK-231	HW9Z-SK-231PN02	2		Controllers
								Operator Interfaces
	e Key Tumber Key)			LW9Z-SK-500	LW9Z-SK-500PN02		Standard key number	Sensors
•		6	Metal (nickel-plated brass)	LW9Z-SK-	LW9Z-SKPN02	2	• Key number : 501 to 503	AUTO-ID
				LW9Z-SK-	LW9Z-SK- PN02		• Key number : 504 to 515	
Lock	sig Ring							ø16
			Polyamide (black) ø28.4 H5 M22P1	HW9Z-LN	HW9Z-LNPN05	5		ø22
Cor	for Mono Jover							ø30 ————————————————————————————————————
Swit	for Mono-lever ch	Ctondord	Nitryl rubber	HWOZ CDM	LIMOZ CDM			Miniature
		Standard	ø10 L20	HW9Z-CPM	HW9Z-CPM	1		Pilot Lights
Boot	for 🔺							
	o-lever	Standard	Nitryl rubber	HW9Z-BLM	HW9Z-BLM	1		HW
OWIL		Staridard	ø29.2 L34.4	oz bew	oz beiti	'		TW
Diffu	sing Lens						Used for LED type jumbo dome pilot	YW
			Polycarbonate ø22.2 H21	HW9Z-PP5C	HW9Z-PP5C	1	lights only. Do not use for incandescent lamp illumination.	
Safe	ty Lever Lock	}	Polyacetal (yellow)	HW9Z-LS	HW9Z-LSPN10	10	A safety lever lock is supplied with a standard HW series switch/pilot light.	
Gasl	xet	>	Nitryl rubber (black)	HW9Z-WM	HW9Z-WMPN10	10	Thickness = 0.5 0.1 6 - 0.15	

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks
Relays & Sockets

Protectors

Power Supplies

LED Illumination

Controllers

Operator

Sensors AUTO-ID

Maintenance Parts All dimensions in mm.

LEDs

Except HW Jumbo Dome Pilot Lights (except colors R, A, and G)

When ordering, specify the Ordering No.

Shape/Dimensions	Operating	Currer	nt Draw	Part No.	Ordering No.	Package	Base	
Shape/Dimensions	Voltage	DC	AC	i ait ivo.	Ordering No.	Quantity	Dase	
LSRD	6V AC/DC	10mA	14mA	LSRD-6	LSRD-6	1		
	OV AC/DC	TOTIA	14111A	LOND-0	LSRD-6PN10	10	DAOC/10	
7 (10// 10// 00	7 4	0 4	LSRD-1	LSRD-1	1		
	12V AC/DC	7mA	8mA	LOND-1	LSRD-1PN10	10	BA9S/13	
	24V AC/DC		0mA	LCDD 2	LSRD-2	1		
			LSRD-2PN10	10				

- Only one color is available for LSRD so there are no codes to specify the color in the part no.
- Use a LSRD-2 lamp for dome pilot lights with Y (yellow), S (blue), or PW (pure white) illumination.
- When replacing the LSTD lamp to LSRD lamp, the lens should also be replaced (see B-219). (except dome pilot lights and dual pushbuttons with pilots)

Accessory for green dual pushbutton (with pilot light)

Package Quantity: 5

Shape	Ordering No.	Dimensions
Attachment lens		
		 For PW (pure white) illumination, use only a LSRD lamp and not an attachment lens. The attachment lens is available with 5 pieces connected as shown on the right.

• See B-227 for the installation method.

For HW Jumbo Dome Pilot Lights

Package Quantity: 1

Shape	Operating Voltage	Current	Draw	Ordering No.	Dimensions
Shape	Operating Voltage	DC	AC	Ordering No.	Difficusions
LSTDB	24V AC/DC	A: 14mA	A: 14mA	LSTDB-2AN	20.5
	24V A0/D0	G: 8mA	G: 8mA	LSTDB-2GN	Eyelet (X1) Voltage

Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

TW

- Use an A (amber) LED for (R) red illumination.
 Use a LSRD-2 lamp for dome pilot lights with V
- Use a LSRD-2 lamp for dome pilot lights with Y (yellow), S (blue), or PW (pure white) illumination.

LED Lamps (LED Lamps for replacing incandescent lamps)

- Use the following replacement LED lamps to replace incandescent lamps,
- See HW series LED lamps shown above for ordering.
- LED lamps may have different brightness/color hue compared with incandescent lamps.

Incandescent Lamp							
Model (dimensions in mm)		Part No.	Rated Voltage	Lamp Ratings	Base		
LS		LS-6	6V AC/DC	1W(6V)			
		LS-8	12V AC/DC	1W(18V)	BA9S/13		
	Glass bulb: ø11	LS-2	AC/DC18V	1W(24V)	DA95/13		
	Length: 23	LS-3	24V AC/DC	1W(30V)			
LSB (For Jumbo D	ome Pilot Lights) Glass bulb: ø10 Length: 27	LSB-2	24V AC/DC	28V/0.17A	BA9S/13		

Replacement LED Lamp						
Ordering No. Rated Voltage		Base				
LSRD-6	6V AC/DC					
LSRD-1	12V AC/DC	BA9S/13				
LSRD-2	24V AC/DC	DA93/13				
LSRD-2	24V AC/DC					
LSTDB-2*	24V AC/DC	BA9S/13				

- Specify a color code in place of *. R (red), G (green), A (amber), S (blue), PW (pure white)
- Use a PW (pure white) LED lamp for Y (yellow) illumination.
- When replacing the incandescent lamp with LSRD, the lens must also be replaced (see B-219).

Transformer

Package Quantity: 1


Shape	Operating Voltage	Operating Voltage Range	Ordering No.	Applicable Load
6V	100/110V AC	100/110V AC ±10%	TWR516	LSRD-6 (6V AC/DC, LED lamp)
	200/220V AC	200/220V AC ±10%	TWR526	LSTD-6* (6V AC/DC, LED lamp) Specify a color code in place of * in Part No.
	400/440V AC	400/440V AC ±10%	TWR546	R (red), G (green), A (amber), S (blue), PW (pure white)
24V	100/110V AC	100/110V AC ±10%	TWR512	LSRD-2 (24V AC/DC, LED lamp)
	200/220V AC	200/220V AC ±10%	TWR522	LSTD-2* (24V AC/DC, LED lamp) or LSTDB-2* (24V AC/DC, LED lamp) Specify a color code in place of * in Part No.
46	400/440V AC	400/440V AC ±10%	TWR542	R (red), G (green), A (amber), S (blue), PW (pure white)

- Terminal cover (TWR-VL3) is installed on transformers as standard.
- Transformer is installed to one HW series unit.

Specifications

Part No.	TWR5□6	TWR5□2		
Operating Voltage	100/110V AC, 200/220V AC 400/440V AC (50/60Hz)			
Current Draw	2.4VA			
Rated Insulation Voltage	600V			
Insulation Resistance	100MΩ minimum (500V I	OC megger)		
Operating Temperature	-30 to +60°C (no freezing)			
Operating Humidity	35 to 85% RH (no condensation)			
Storage Temperature	-40 to +80°C (no freezing)			
Vibration Resistance	Damage limits: 30Hz, am Operating extremes: 5 to			
Shock Resistance	Damage limits: 1,000 m/s Operating extremes: 100			
Dielectric Strength	2500V AC, 1 minute			
Terminal Screw	M3.5			
Applicable Wire	2mm² maximum, 2 wires maximum			
Weight (approx.)	87g			

Dimensions



All dimensions in mm.

ø16

Accessories

When ordering, specify the Ordering No.

Shape	Material	Part No.	Ordering No.	Package Quantity	Dimensions (mm)
DIN 35 mm Rail Weight: 200g approx.	Aluminum Length: 1000 mm	BAA1000	BAA1000PN10	10	12.5 12.5 1.7 8 8 8
End Clip Weight: 15g approx.	Metal (zinc-plated steel) Applicable rail: AA1000	BNL6	BNL6PN10	10	M4 Screws M4 Screws 45

• See H-071 for DIN rail products.

APEM

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets Circuit Protectors

Power Supplies

LED Illumination

Controllers Operator

Sensors

AUTO-ID

Flush Silhouette

ø30

Miniature

Pilot Lights

TW

Safety Precautions

 Turn off the power to the HW series switches & pilot lights before starting installation, removal, wiring, maintenance, and starting installation, removing, wiring, maintenance, and inspection of the products. Failure to turn power off may cause electrical shocks or fire hazard.

 To avoid a burn on your hand, use the lamp holder tool when replacing lamps. For wiring, use wires of a proper size to meet the voltage and current requirements. Tighten the terminal screws to the recommended tightening torque (see B-228). Failure to tighten terminal screws may cause overheat and fire.

APEM

Pilot Lights

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit
Protectors

Power Supplies

LED Illumination

Controllers Operator

Sensors

AUTO-ID

Flush Silhouette

ø16 ø22 ø30

Miniature

Pilot Lights




Operating Instructions

Panel Mounting

Remove the contact block from the operator (for transformer type pilot lights, remove the transformer from the illumination unit).
 Remove the locking ring from the operator (for pilot lights, remove the locking ring from the

illuminated unit). Insert the operator into the panel cut-out from the front. Tighten the locking ring from the back to install the contact block to the operator.



Mounting panel thickness is reduced by 1.5 mm when using a nameplate.

Removing the Contact Block

Non-illuminated switches


- Remove the operator from the contact block by pushing in the direction shown in ① and then turn the lever to the left shown in ②.
 Then the operator can be pulled out.
- 2) To reinstall, place the TOP marking on the operator and the lock lever in the same direction, and insert the operator into the contact block mounting adapter. Then turn the locking lever in the opposite direction.






Illuminated switches

 Remove the safety lever lock (yellow) from the lock lever by inserting a flat screwdriver into the safety lever lock and push upwards.



 Remove the operator from the contact block by turning the locking lever in the direction of the arrow shown below. Then the operator can be pulled out.



- To reinstall, place the TOP marking on the operator and the lock lever in the same direction, and insert the operator into the contact block mounting adapter. Then turn the locking lever in the opposite direction
- Install the safety lever lock (yellow) on the lock lever. The safety lever lock cannot be installed when the lock lever is not upright.

Safety Lever Lock

IDEC strongly recommends using the safety lever lock (HW9Z-LS, yellow) to ensure that lock lever is locked, or to prevent maintenance personnel from unlocking contacts during wiring.



How to install

 Mount the HW series onto the panel, lock the lever, and push in the safety lever lock.

Spacing in Vertical Direction

 Be sure to take the space required for installing/removing the safety lever lock into consideration. When the spacing is narrower than the recommended value, install the HW series units in the order of low to high. When removing, do so in the opposite direction.

Notes for Panel Mounting

Locking ring wrench recommended torque

Tighten the bezel to a tightening torque of 2.0 N·m.

Locking ring wrench

Locking ring wrench (MW9Z-T1) can be used to tighten the bezel. Do not use pliers. Excessive tightening will damage the locking ring.



Locking ring wrench (MW9Z-T1)

Panel Thickness

HW series can be mounted on a panel with thickness of 0.8 to 6.0 mm. Take the thickness of nameplate and/or switch guard into consideration.

Replacement of LED Lamps

LED lamps can be replaced by using the lamp holder tool (OR-55) from the front of the panel, or by removing the contact block from the operator unit. (See B-217 for lamp holder tool.)

How to Remove


To remove, slip the lamp holder tool onto the lamp head lightly. Then push slightly, and turn the lamp holder tool counterclockwise.




Photo: Extended pilot light

How to Install

Insert the lamp head into the lamp holder tool.



Place the pins on the lamp base to the grooves in the lamp socket. Insert the lamp and turn it clockwise.



Installing/Removing the Buttons and Lenses

<To install>

<To remove>

Pushbutton Button

Flush/Extended

Push in the button to install.



Insert a flat screwdriver between the button and the bezel to remove the button.



Mushroom/Jumbo Mushroom

Button has threads. Turn clockwise to install the button.



Turn the button counterclockwise to remove.

Note: Jumbo mushroom button cannot be removed.



Illuminated Pushbutton Lens

• Flush/Extended

Push in the lens holder into the operator unit.



Insert a flat screwdriver between the button and the bezel to remove the lens holder.



• Mushroom/Jumbo Mushroom

Lens has threads. Turn clockwise to install the lens.



Lens has threads. Turn counterclockwise to remove the lens.



Pilot Light Lens

Extended/Mushroom

Lens has threads. Turn clockwise to install the lens.



Turn the lens counterclockwise to remove.



• Round Flush/Square Flush

Push in the lens holder into the operator unit.



Insert a flat screwdriver between the lens and the bezel to remove.



Removing the Contact Blocks/Full Voltage Adapters

Insert a flat screwdriver (4 to 6 mm) into the snap-fit latches of the contact block or full voltage adapter and lift to remove.




- Make sure to lift both latches.
 Contact blocks cannot be removed by lifting one latch only.
- Do not apply excessive force to the latches, otherwise damage maybe caused.

Transformer Units and DC-DC Converters

Insert the end of the contact block removal tool (TW-KC1) into the snap-fit latch of the transformer units or DC-DC converter and pull the tool forward.

The contact block removable tool cannot be used to remove the HW-U contact blocks (HW-U), full voltage adapters (HW-GA1N), or dummy blocks (HW-DB).



Transformer Units and DC-DC Converters for Pilot Lights

Insert a flat screwdriver into the snap-fit latch on the contact block and lift to remove.



when replacing parts (contact block, dummy block, full voltage adapter, transformer) for maintenance, make sure to install the parts to the original position. Otherwise proper operation cannot be guaranteed.



Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø30

Miniature

Pilot Lights

HW TW

Using a Ring Adapter

HW9Z-A25

Install the ring adapter between the HW series unit and panel. Make sure that the side with ridges face the panel.

APFM

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Power Supplies

Protectors

LED Illumination

Controllers

Operator Interfaces

AUTO-ID

Sensors

Flush Silhouette

ø30

Miniature

Pilot Lights

TW







Installation The bezel protrudes 0.5 mm to the front if the gasket is not removed. Locking Ring Ring Adapter




HW9Z-A30


Washer

metal (brass)

The ring adapter HW9Z-A30 consists of a washer and adapter. Install adapter between the HW series unit and panel. Install washer between the locking ring and panel.







Replacement of Lens and Marking Plate

Removing the Lens Unit

Remove the lens unit (color lens, marking plate, and lens holder) by inserting a small flat screwdriver into the recess of the lens through the bezel. Knob on illuminated selector switches can be removed by tilting sideways. No tool is required.



Removing the Lens

Remove the lens by pushing the lens from the rear to disengage the latches between the lens and the lens holder, using a flat screwdriver as shown below. Marking plate can be removed after the lens is removed from the lens holder.





Note: The translucent filter in the lens holder cannot be removed because this filter is sealed to make the unit waterproof and oiltight.

Installing

[For Round Lens]

Lens Marking Plate Lens Holder

- 1. Place the marking plate on the lens holder with the anti-rotation projection engaged and press the lens onto the lens holder to engage the latches.
- 2. Place the marking plate in the correct orientation.

[For Square Lens]

Lens Marking Plate Lens Holder

- 1. Place the marking plate on the lens holder and press the lens onto the lens holder to engage the latches.
- 2. Place the marking plate in the correct orientation (note the directionality of marking plate).










Marking

For HW series illuminated pushbuttons and pilot lights, legends and symbols can be engraved on the built-in marking plates, or printed film can be inserted under the lens for labeling purposes. Films are not supplied with illuminated pushbuttons, and may be provided by the user.


Lens Style	Round Lens (Round Flush/Round Flush with Square Bezel)	Square Lens (Square Flush)			
Built-in Marking Plate	Engraving Area ø19.6 Outside diameter ø21.5	Engraving Area 19.9 19.9 19.9 19.9 Outside diameter 22.7			
	Engraving must be made on the engraving area within 0.5 mm deep. The marking plate is made of white acrylic resin.				
Applicable Marking Film	99	22.7			
	Two 0.1 mm-thick films or one 0.2 mm-thick film can be installed in the lens (marking film is not supplied and must be provided by the user). Recommended marking film: polyester				

Insertion Order of Marking Plate and Film [Round Lens]



Note: Films are not supplied.

[Square Lens]



Note: Films are not supplied. When inserting a film, make sure that the marking plate is installed with its uneven side facing the lens holder.

Nameplate

Mounting panel thickness is reduced by 1.5 mm when using a nameplate.


Installing a Marking Plate

Insert a marking plate tin the direction of the arrow \mathbb{O} , and press in as shown \mathbb{Q} .



Removing a Marking Plate

Insert a flat screwdriver into the upper middle part of the marking plate and remove. When anti-rotation is not required, remove the projection from the nameplate using pliers.



Replacing the Lens of Dual Pushbuttons Removing

Remove the lens by inserting a small flat screwdriver into the recess of the lens through the bezel.



Installing

Install the lens in the recess between the buttons by pressing against the bezel.

Selector Switches


Turn the operator such as knob, lever, and key to each position accurately. Releasing halfway may cause the operator to return to the former position, or to get stuck between. On spring return two-way types, the center of operators may be misaligned slightly.

Key Selector Switches

Insert the key completely before turning. Failure to do so may cause failures


Anti-rotation Ring and Panel Cut-out

Align the TOP marking on the operator, TOP marking on the antirotation ring with the recess in the mounting panel.



Dual Pushbutton Switches

The pushbuttons cannot be removed or replaced. Do not attempt to remove using a flat screwdriver or pincers, otherwise the pushbuttons may be damaged.




Installing the Rubber Boot for Dual Pushbuttons

When using the HW7D pushbuttons in places where the pushbuttons are subject to water splash or an excessive amount of dust, make sure to use the HW9Z-D7D rubber boot (IP65) which is ordered separately. Recombs the rubber gasket pre-installed on the operator, and install the rubber boot from the front of buttons.

Notes for Installing the Rubber Boot

Remove the gasket from the operator, and install the rubber boot on the operator. Pull out the seals of the rubber boot and place them around the operator sleeve as shown. Make sure that the seals are not twisted or tucked inside and that the gasket does not remain, otherwise the normal waterproof and dustproof characteristics are not ensured.



Rubber Boot Installed



APEM

Switches &

Control Boxes

Emergency Stop Switches Enabling

Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Protectors

Power Supplies

LED Illumination

Controllers Operator

Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø22

ø30 Miniature

Pilot Lights

HW TW



Close Mounting

When mounting the units closely in a horizontal row on 30 mm centers, use optional barriers to prevent interconnection between adjoining terminals, and to increase the creepage distance. The barriers can be attached simply by pressing them onto the sides of contact blocks.

APEM
Switches &
Pilot Lights

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Power Supplies

Protectors

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID


Flush Silhouette



Miniature

Pilot Lights






Use a barrier (HW-VU1) between the contact blocks.

Note: Sufficient insulation distance cannot be obtained if barriers are not installed, or when other barriers such as HW-VG1 is used.


When using transformer type illuminated HW series of 240V AC maximum closely in a horizontal row on 30 mm centers, insert straight the solid wires or stranded wires into inside of the terminal screw on the transformer (see figure below) to prevent short circuit between adjoining terminals.




When using transformer type pilot lights closely mounted in horizontal and vertical rows on 30 mm centers, keep the ambient temperature below 40°C.

Installing the attachment lens

Install the lens on to the LED lamp with the lens remaining on the runner. (The lens will be cut off when installed). Note the front and back sides of the lens.





Applicable Wiring


(1) Contact Block 0.3 to 3.5 mm² (solid wire Ø0.5 to 2.0 mm)

Pushbutton/illuminated pushbutton/dual pushbuttons (without pilot light), selector switch, illuminated selector switch, pushbutton selector, mono-lever switch

(A) and (B) show the wiring direction to the terminals.

<Contact Block>


Terminal screws M3.5 (spring-up)




Applicable Crimping Terminal


Be sure to use an insulation tube or cover on the crimping part of the crimping terminal to prevent electrical shocks.

Crimping terminal for (A)







IP20 crimping terminal



Crimping terminal for (B) (IP20)



Solid wire



- Strip the wire insulation 8 to 9 mm from the end.
- Insert the wire until the insulation comes into contact with the terminal metal part.

(1)-1 IP20 Degree of Protection

The terminal of HW-U contact block has IP20 degree of protection. When IP20 is required for wiring, observe the followings. Make sure to insert the crimping terminal or wire to the terminal straight and fully.

When using a crimping terminal

Use IP20 crimping terminals.

When using a solid wire

Strip the wire insulation 8 to 9 mm from the end and insert the wire to the terminal fully.

When using a stranded wire

Strip the wire insulation 8 to 9 mm from the end and insert the wire to the terminal fully. Make sure that the wires are not loosened.


(2) Power Unit 0.3 to 2 mm² (solid wire Ø0.5 to 1.6 mm)

Illuminated pushbutton/illuminated selector switch

(A) and (B) show the wiring direction to the terminals.

<Full Voltage Adapter>

Terminal screws M3.5 (spring-up)



<Transformer Unit>

100/110V AC. 200/220V AC Terminal screws M3.5 (spring-up)



<DC-DC Convertor Unit/Transformer Unit>


110V DC. 380V AC minimum Terminal screws M3.5 (spring-up)




Applicable Crimping Terminal

Be sure to use an insulation tube or cover on the crimping part of the crimping terminal to prevent electrical shocks.


Crimping terminal for (A)







Solid wire



- Strip the wire insulation 7 to 8 mm from the end.
- Insert the wire until the insulation comes into contact with the terminal metal part,

Terminal cover is integrated in the full voltage adapter and transformer unit. Note that the connection terminal is not IP20.

(2) Pilot Light 0.3 to 2 mm² (solid wire Ø0.5 to 1.6 mm) (Arrows show the wiring direction)


<Full Voltage Adapter>

6. 12. 24V AC/DC

Terminal screws M3.5 (spring-up)




<Transformer, DC-DC Converter> 100/110V AC, 200/220V AC 110V DC, 380V AC minimum Terminal screws M3.5 (spring-up)



Applicable Crimping Terminal

Be sure to use an insulation tube or cover on the crimping part of the crimping terminal to prevent electrical shocks.



Solid Wire

- Strip the wire insulation 8 to 9 mm from the end.
- . Inset the wire until the insulation comes into contact with the terminal metal part,
- · Terminal cover is integrated but not IP20.
- . When selecting mounting centers and crimping terminals, take sufficient insulation distance into consideration.

8 to 9mm

Cautions for Wiring

About DC-DC Converter Unit

1. Note the polarity for wiring when connecting to the DC-DC converter.

Terminal No.	Polarity		
X1	Positive		
X2	Negative		

- 2. Incandescent lamps cannot be used in DC-DC converter unit.
- 3. DC-DC converters are equipped with an electric circuit and noise may be heard inside the unit, which does not affect the performance of DC-DC converters.

Recommended Tightening Torque

Number Recommended Terminal					
Unit Wire		Wire	of Wires	Tightening Torque	Screw
HW-U Contact Block	Crimping Terminal		2	1.0 to 1.3	
	So l id Wire	ø0.5 to 1.6 mm (AWG14 to 22)	2	1.0 to 1.3	M3.5
		ø1.7 to 2.0 mm (AWG12)	1	1.2 to 1.3	
	Stranded Wire	0.3 to 2.0 mm ² (AWG14 to 22)	2	1.0 to 1.3	
		2.1 to 3.5 mm ² (AWG12)	1	1.2 to 1.3	
Illuminated Unit (*1)	Crimping Terminal				
	So l id Wire	ø0.5 to 1.6 mm (AWG14 to 22)	2	1.0 to 1.3	M3.5
	Stranded Wire	0.3 to 2.0 mm ² (AWG14 to 22)			
Pilot Light	Crimping Terminal				
	So l id Wire	Ø0.5 to 1.6 mm (AWG14 to 22)	2	1.0 to 1.3	M3.5
	Stranded Wire	0.3 to 2.0 mm ² (AWG14 to 22)			

*1) Lamp terminal of illuminated pushbuttons, illuminated selector switches, dual pushbuttons with pilot lights

APFM

Control Boxes

Emergency Stop Switches Enabling

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit

Protectors Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

Number of Wires

	ø22			
3.5	ø30			
	Miniature			
	Pilot Lights			
3.5	HW			
	TW			
	YW			
3.5				

SAPEN01A_B HW January 2023

Ordering Terms and Conditions

Thank you for using IDEC Products.

By purchasing products listed in our catalogs, datasheets, and the like (hereinafter referred to as "Catalogs") you agree to be bound by these terms and conditions. Please read and agree to the terms and conditions before placing your order.

1. Notes on contents of Catalogs

- (1) Rated values, performance values, and specification values of IDEC products listed in this Catalog are values acquired under respective conditions in independent testing, and do not guarantee values gained in combined conditions.
 - Also, durability varies depending on the usage environment and usage conditions.
- (2) Reference data and reference values listed in Catalogs are for reference purposes only, and do not guarantee that the product will always operate appropriately in that range.
- (3) The specifications / appearance and accessories of IDEC products listed in Catalogs are subject to change or termination of sales without notice, for improvement or other reasons.
- (4) The content of Catalogs is subject to change without notice.

2. Note on applications

- If using IDEC products in combination with other products, confirm the applicable laws / regulations and standards.
 - Also, confirm that IDEC products are compatible with your systems, machines, devices, and the like by using under the actual conditions. IDEC shall bear no liability whatsoever regarding the compatibility with IDEC products.
- (2) The usage examples and application examples listed in Catalogs are for reference purposes only. Therefore, when introducing a product, confirm the performance and safety of the instruments, devices, and the like before use. Furthermore, regarding these examples, IDEC does not grant license to use IDEC products to you, and IDEC offers no warranties regarding the ownership of intellectual property rights or non-infringement upon the intellectual property rights of third parties.
- (3) When using IDEC products, be cautious when implementing the following.
 - i. Use of IDEC products with sufficient allowance for rating and performance
 - Safety design, including redundant design and malfunction prevention design that prevents other danger and damage even in the event that an IDEC product fails
 - Wiring and installation that ensures the IDEC product used in your system, machine, device, or the like can perform and function according to its specifications
- (4) Continuing to use an IDEC product even after the performance has deteriorated can result in abnormal heat, smoke, fires, and the like due to insulation deterioration or the like. Perform periodic maintenance for IDEC products and the systems, machines, devices, and the like in which they are used.
- (5) IDEC products are developed and manufactured as general-purpose products for general industrial products. They are not intended for use in the following applications, and in the event that you use an IDEC product for these applications, unless otherwise agreed upon between you and IDEC, IDEC shall provide no guarantees whatsoever regarding IDEC products.
 - i. Use in applications that require a high degree of safety, including nuclear power control equipment, transportation equipment (railroads / airplanes / ships / vehicles / vehicle instruments, etc.), equipment for use in outer space, elevating equipment, medical instruments, safety devices, or any other equipment, instruments, or the like that could endanger life or human health
 - Use in applications that require a high degree of reliability, such as provision systems for gas / waterworks / electricity, etc., systems that operate continuously for 24 hours, and settlement systems
 - iii. Use in applications where the product may be handled or used deviating from the specifications or conditions / environment listed in the Catalogs, such as equipment used outdoors or applications in environments subject to chemical pollution or electromagnetic interference If you would like to use IDEC products in the above applications, be sure to consult with an IDEC sales representative.

3. Inspections

We ask that you implement inspections for IDEC products you purchase without delay, as well as thoroughly keep in mind management/maintenance regarding handling of the product before and during the inspection.

4. Warranty

(1) Warranty period

The warranty period for IDEC products shall be one (1) year after purchase or delivery to the specified location. However, this shall not apply in cases where there is a different specification in the Catalogs or there is another agreement in place between you and IDEC.

(2) Warranty scope

Should a failure occur in an IDEC product during the above warranty period for reasons attributable to IDEC, then IDEC shall replace or repair that product, free of charge, at the purchase location / delivery location of the product, or an IDEC service base. However, failures caused by the following reasons shall be deemed outside the scope of this warranty.

- i. The product was handled or used deviating from the conditions / environment listed in the Catalogs
- ii. The failure was caused by reasons other than an IDEC product
- iii. Modification or repair was performed by a party other than IDEC
- iv. The failure was caused by a software program of a party other than IDEC
- The product was used outside of its original purpose
- vi. Replacement of maintenance parts, installation of accessories, or the like was not performed properly in accordance with the user's manual and Catalogs
- vii. The failure could not have been predicted with the scientific and technical standards at the time when the product was shipped from IDEC.
- viii. The failure was due to other causes not attributable to IDEC (including cases of force majeure such as natural disasters and other disasters)
 Furthermore, the warranty described here refers to a warranty on the IDEC product as a unit, and damages induced by the failure of an IDEC product are excluded from this warranty.

5. Limitation of liability

The warranty listed in this Agreement is the full and complete warranty for IDEC products, and IDEC shall bear no liability whatsoever regarding special damages, indirect damages, incidental damages, or passive damages that occurred due to an IDEC product.

Service scope

The prices of IDEC products do not include the cost of services, such as dispatching technicians. Therefore, separate fees are required in the following cases.

- (1) Instructions for installation / adjustment and accompaniment at test operation (including creating application software and testing operation, etc.)
- (2) Maintenance inspections, adjustments, and repairs
- (3) Technical instructions and technical training
- (4) Product tests or inspections specified by you

The above content assumes transactions and usage within your region. Please consult with an IDEC sales representative regarding transactions and usage outside of your region. Also, IDEC provides no guarantees whatsoever regarding IDEC products sold outside your region.

IDEC CORPORATION

Head Office 6-64, Nishi-Miyahara-2-Chome, Yodogawa-ku, Osaka 532-0004, Japan

www.idec.com

USA IDEC Corpo EMEA APEM SAS

IDEC Corporation APEM SAS Singapore IDEC Izumi Asia Pte. Ltd.
Thailand IDEC Asia (Thailand) Co., Ltd.
IDEC Controls India Private Ltd.

China IDEC (Shanghai) Corporation IDEC Izumi (H.K.) Co., Ltd.

Taiwan IDEC Taiwan Corporation

Japan IDEC Corporation

